



DOC18/410834-01

Ms Jessie Evans
Department of Planning and Environment
GPO Box 39
SYDNEY NSW 2001

Dear Ms Evans

Dendrobium Coal Mine – Modification 8 (DA 60-03-2001 MOD 8)

I am writing in reply to the Department of Planning and Environment's request dated 20 June 2018 for comments on the modification application above.

The application was submitted by Illawarra Coal Pty Ltd for the installation of a kiosk-style electricity transformer at the Dendrobium coal mine. The coal mine is regulated under the Environment Protection Authority's (EPA) licence number 3241.

The EPA has reviewed the application and provides the following comments on the proposal.

1. The development must comply with the Protection of the Environment Operations Act 1997 and any associated regulations at all times.
2. Any transformer containing oil must be contained in an bunded area designed, operated and maintained in accordance with relevant guidelines/Australian Standards.
3. The modification, if approved, does not require a change to the EPA licence however any development activities must be undertaken to ensure compliance with the licence.

If you have questions regarding the above, please phone the contact officer on (02) 4224 4100.

Yours sincerely

A handwritten signature in black ink, appearing to be 'PB', followed by the date '03/07/18' written in a similar style.

PETER BLOEM
Manager Regional Operations Illawarra
Environment Protection Authority

Contact officer: Andrew Couldridge
(02) 4224 4100




Figure 1- Proposed Dendrobium Surface Kiosk Supply

