

All communications to be addressed to:

Headquarters
NSW Rural Fire Service
Locked Mail Bag 17
GRANVILLE NSW 2142

Headquarters
NSW Rural Fire Service
15 Carter Street
HOMEBUSH BAY NSW 2127

Telephone: (02) 8741 5555
e-mail: development.assessment@rfs.nsw.gov.au

Facsimile: (02) 8741 5550



Director General
Dept. Of Planning - Urban
GPO Box 39
Sydney NSW 2001

Your Ref: DA 2002-3-77 MOD 6

Our Ref: D11/0925
DA11061578305 MH

19 July 2011

ATTENTION: Mark Schofield

Dear Mr Schofield

Integrated Development for 81//1158006 George Bass Drive Barlings Beach

I refer to your letter dated 10 June 2011 seeking advice regarding bush fire protection for the above Part 3A Development.

Based on the plans and documentation received within the environmental assessment, the RFS advises the development should address the following numbered conditions:

1. The ability to site and provide for adequate water supplies for bush fire suppression operations;
2. Providing adequate egress/access to the proposed development as outlined within 4.1.3 of *Planning for Bush Fire Protection 2006*;

For any enquiries regarding this correspondence please contact Mark Hawkins on 8867 7967.

Yours sincerely,



Nika Fomin

Team Leader – Development Assessment

The RFS has made getting additional information easier. For general information on *Planning for Bush Fire Protection 2006*, visit the RFS web page at www.rfs.nsw.gov.au and search under *Planning for Bush Fire Protection 2006*.