

The proposal will connect to Transgrid network, not Essential Energy's. However, Essential Energy does have an 11kV powerline that dissects the site as indicated in the map below by the blue line.

I would request that the developer speak to EE about the position of assets within that corridor, or apply to relocate the powerline, which can be assessed separately under Part 5.

A lot of EE assets are not covered by easements, but have protections similar to an easement under s53 of the Electricity Supply Act 1995.

