



Office of
Environment
& Heritage

DOC19/118309 -1
Email of 1 March 2019

Lawren Drummond
Planning Officer
Regional Assessments
Department of Planning and Environment
Lawren.drummond@planning.nsw.gov.au

Dear Lawren

Notification of Modification Request - 21 Honeysuckle Drive, Newcastle (SSD 8019 MOD 1)

I refer to your email of the 6 December 2018 in which you asked the Office of Environment and Heritage to review and comment on the proposed modifications to the conditions of consent for 21 Honeysuckle Drive (SSD8019).

OEH has reviewed the proposed modifications for flooding and flood risk and notes that the proponent is seeking Amendment to Conditions B23 and B24 by reducing the probable maximum flood planning level from RL3.65m to RL3.40m to reflect the revised levels from the Honeysuckle Redevelopment Area Flood Study, (BMT, 2018). OEH has reviewed the study and is satisfied with the proposed modification conditions for flood management.

If you require any further information regarding this matter, please contact Steve Crick, Senior Team Leader, Water Floodplains & Coast, on 4927 3246 or via email at rog.hcc@environment.nsw.gov.au.

Yours sincerely

SHARON MOLLOY
Director Hunter Central Coast Branch
Conservation and Regional Delivery Division