18th March 2021



Project No. 6817000 Revision No. 01

Tina Tang Jattca Property Solutions Suite 101, Level 1, 343 George Street Sydney NSW 2000

Dear Tina,

RE: Weigall Sports Complex - Sydney Grammar School (SSD-10421)

We have reviewed the letter received from Sydney Water dated 15th March 2021 and specifically in relation to the stormwater items. Sydney Water has indicated that there is a conflict between the proposed development and a 860mm x 990mm stormwater channel.

Please find enclosed the below listed Warren Smith Consulting Engineers drawings which illustrate the location of the existing easement as well as the stormwater assets. The drawings indicate that there is worst case a 4 metre clearance between the existing Sydney water assets and the proposed building which exceeds the minimum 1m requirements.

Enclosed

- Drawing C1.03 Issue 3 Existing Survey
- Drawing C6.02 Issue 3 Stormwater Plan Sheet 1
- Drawing C6.04 Issue 3 Stormwater Plan Sheet 3
- Drawing A2101 Building 01 Sports Facilities Building General Arrangement Plan Ground Issue A

Please contact me if you have any questions on this.

Yours faithfully,

WARREN SMITH CONSULTING ENGINEERS PTY LIMITED

Michael Cahalane

<u>Director - Civil & Water Engineering</u>

Mobile: 0433 522 569

Email: michael@warrensmith.com.au

WARREN SMITH CONSULTING ENGINEERS PTY LTD		SINCE 1981.	NSW	VIC
ACN 002 197 088	ABN 36 300 430 126	wsp@warrensmith.com.au	Level 9, 233 Castlereagh St Sydney 2000 NSW Australia	Level 20/485 La Trobe St Melbourne 3000 Vic Australia
■ Hydraulic ■ Fire ■ Civil ■ Utilities Infrastructure		www.warrensmith.com.au	PH +61 (2) 9299 1312	PH +61 (3) 8648 9942







