

From: Airport Developments
To: [Luisa Maguire](#); [Teresa Gizzi](#)
Cc: [Airspace.Protection \(Airspace.Protection@casa.gov.au\)](mailto:Airspace.Protection@casa.gov.au)
Subject: AIRSERVICES RESPONSE: NSW-MA-581 - Dev, Nepean Hospital (SSD 8766) [SEC=UNCLASSIFIED]
Date: Monday, 8 October 2018 11:07:59 AM
Attachments: [image001.png](#)

Hi Luisa and Teresa,

I refer to your request for an Airservices assessment of the Nepean Hospital and Integrated Ambulatory Services Redevelopment at 35-65 Derby Street, Kingswood.

Airspace Procedures

With respect to procedures designed by Airservices in accordance with ICAO PANS-OPS and Document 9905, at a maximum height of 116.82m (384ft) AHD, the property development will not affect any sector or circling altitude, nor any instrument approach or departure procedure at RAAF Richmond, Camden, and Bankstown Airport and Westmead Hospital helicopter landing site.

The property development will not affect the Sydney RTCC.

Note that procedures not designed by Airservices at RAAF Richmond, Camden, and Bankstown Airport and Westmead Hospital helicopter landing site were not considered in this assessment.

Communications/Navigation/Surveillance (CNS) Facilities

This property development, to a maximum height of 116.82m (384ft) AHD, will not adversely impact the performance of Precision/Non-Precision Navigational Aids, HF/VHF Comms, A-SMGCS, Radar, PRM, ADS-B, WAM or Satellite/Links.

Kind regards,

William Zhao

Advisor Airport Development | Operations Standards & Assurance

Airservices Australia

Phone: +61 3 9339 2504

Email: airport.developments@airservicesaustralia.com

www.airservicesaustralia.com

CAUTION: This e-mail is confidential. If you are not the intended recipient, you must not disclose or use the information contained in it. If you have received this e-mail in error, please tell us immediately by return e-mail and delete the document. Airservices Australia does not represent, warrant or guarantee that the integrity of this communication is free

From: Airport Developments

Sent: Tuesday, September 18, 2018 1:22 PM

To: Luisa Maguire <Luisa.Maguire@planning.nsw.gov.au>; Teresa Gizzi <Teresa.Gizzi@planning.nsw.gov.au>

Subject: NSW-MA-581 - Dev, Nepean Hospital [SEC=UNCLASSIFIED]

Hi Luisa and Teresa,

I have received your proposal and commenced the Airservices assessment, which takes approximately 6 weeks for completion.

If you have any questions, please contact the Airport Developments team and quote assessment code: NSW-MA-581

Please note that all completed Airservices assessments are also forwarded to CASA.

Regards,

William Zhao

Advisor Airport Development | Operations Standards & Assurance

Airservices Australia

Phone: +61 3 9339 2504

Email: airport.developments@airservicesaustralia.com

www.airservicesaustralia.com

CAUTION: This e-mail is confidential. If you are not the intended recipient, you must not disclose or use the information contained in it. If you have received this e-mail in error, please tell us immediately by return e-mail and delete the document. Airservices Australia does not represent, warrant or guarantee that the integrity of this communication is free

From: Luisa Maguire [<mailto:Luisa.Maguire@planning.nsw.gov.au>]

Sent: Monday, September 10, 2018 11:13 AM

To: Airport Developments <Airport.Developments@AirservicesAustralia.com>

Subject: Exhibition of Nepean Hospital and Integrated Ambulatory Services Redevelopment (Stage 1) - (SSD 8766)

Good Morning,

Please find attached the Exhibition of Nepean Hospital and Integrated Ambulatory Services Redevelopment (Stage 1) 35-65 Derby Street, Kingswood (SSD 8766).

The SSD Application and accompanying documents may be viewed on the department's website at http://majorprojects.planning.nsw.gov.au/index.pl?action=view_job&job_id=8766.

The Department of Planning and Environment invites you to comment on the proposal by close of business **Thursday 11 October 2018**.

If you have any questions, please contact Teresa Gizzi on (02) 8275 1124 or via email at Teresa.Gizzi@planning.nsw.gov.au.

Regards

Luisa Maguire

Luisa Maguire

DA Coordinator | Key Sites and Industry Assessments

Department of Planning & Environment

320 Pitt Street | GPO Box 39 | Sydney NSW 2001

T 02 8289 6757 E luisa.maguire@planning.nsw.gov.au

