



NSW RURAL FIRE SERVICE

Department of Planning and Environment (Sydney Offices)
GPO Box 39
Sydney NSW 2001

Your reference: SSD-9679
Our reference: DA20210201000357-SEARS-1

ATTENTION: Anthony Ko

Date: Wednesday 10 March 2021

Dear Sir/Madam,

State Significant Development – Electricity Generating Works
Request for comments – exhibited Environmental Impact Statement (EIS)
Morrison's Gap Road HANGING ROCK NSW 2340, 31//DP804711

Reference is made to correspondence dated 01/02/2021 seeking comments regarding the Environmental Impact Statement (EIS) currently being exhibited, for the above State Significant Development in accordance with the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has reviewed the EIS and provides the following comments;

The bush fire risk management strategies - table 13.11, as reported in section 13.4 of the Environmental Impact Assessment shall be incorporated in any consent granted. The Bush Fire Risk Management Strategy shall also include a detail site plan identifying, using GPS coordinates, each turbine tower location and be incorporated into the Bush Fire Emergency Management and Operations Plan. A copy of the plan shall be stored at the NSW RFS Liverpool Range District office.

For any queries regarding this correspondence, please contact Alan Bawden on 1300 NSW RFS.

Yours sincerely,

Timothy Carroll
Manager Planning & Environment Services
Planning and Environment Services

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au