



Australian Government
Civil Aviation Safety Authority

STAKEHOLDER ENGAGEMENT DIVISION

CASA Ref: GI18/536

25 July 2018

Mr David Glasgow
A/Team Leader
Key Sites Assessments
Department of Planning and Environment
GPO Box 39
SYDNEY NSW 2001

Email: david.glasgow@planning.nsw.gov.au

Dear Mr Glasgow

Thank you for your letter of 11 July 2018 addressed to the Airspace Protection email address at the Civil Aviation Safety Authority (CASA) requesting comment on the amended concept proposal for the redevelopment of Cockle Bay Wharf (SSD 7684).

CASA has reviewed the response to submissions and I am advised that the maximum height of the building envelope will be 183m Australian Height Datum (AHD) which will infringe prescribed airspace for Sydney Airport by penetrating the Outer Horizontal Surface (elevation 156m AHD). Therefore, the proposal will require a controlled activity approval from the Department of Infrastructure, Regional Development and Cities (DIRDC) as the administrator of the Airports (Protection of Airspace) Regulations 1996 (Regulations).

In accordance with the Regulations the proponent should seek the controlled activity approval through Sydney Airports Corporation Ltd (SACL). SACL will confirm the infringement and obtain comments from stakeholders, including CASA and Airservices Australia, and refer the application to DIRDC. CASA will assess the building from an obstacle perspective when a request for comment is received from SACL.

For more information or to discuss this matter further please email:
anaa.corro@casa.gov.au.

I trust this information is of assistance.

Yours sincerely

A handwritten signature in dark ink, appearing to read 'Hutton'.

Carolyn Hutton
Branch Manager
Government and International Relations