

STAKEHOLDER ENGAGEMENT DIVISION

CASA Ref: GI18/125

February 2018

Ms Karen Harragon Director Social and Other Infrastructure Assessments Department of Planning and Environment GPO Box 39 SYDNEY NSW 2001

Email: Luisa.maguire@planning.nsw.gov.au

Dear Ms Harragon

Thank you for your letter of 12 February 2018 requesting comment from the Civil Aviation Safety Authority (CASA) on a development application for the development of the Health Services Administration Building located at Royal North Shore Hospital, St Leonards.

CASA has reviewed the application, including the Aviation Assessment contained at Appendix BB, and I am advised that the proposed building at a height of 126.0 m above Australian Height Datum (AHD) will be under the Obstacle Limitation Surfaces (OLS) for Sydney Airport (156m AHD) and therefore does not need to be assessed by CASA. If the cranes will infringe the OLS for Sydney Airport, the crane operation proposal should be referred to Sydney Airport Corporation Limited.

I trust this information is of assistance.

Yours sincerely

Carolyn Hutton Branch Manager

Government and International Relations