

TELEPHONE: (02) 6542 9068

EMAIL: jobrien@ausgrid.com.au

ATTN: Rachel Carss Level 16, 12 Darcy Street, Parramatta, NSW 2150 570 George Street
Sydney NSW 2000
All mail to GPO Box 4009
Sydney NSW 2001
T +61 2 131 525
F +61 2 9269 2830
www.ausgrid.com.au

Re: SSD-10418 - MOUNT PLEASANT OPTIMISATION PROJECT

With regard to Mount Pleasant Optimisation Project at 1100 Wybong Road, Muswellbrook Ausgrid consents to the above mentioned development subject to the following conditions:-

Overhead Powerlines

Safework NSW Document – Work Near Overhead Powerlines: Code of Practice, outlines the minimum safety separation requirements between these mains/poles to structures within the development throughout the construction process. It is a statutory requirement that these distances be maintained throughout construction. Special consideration should be given to the positioning and operating of cranes and the location of any scaffolding.

The "as constructed" minimum clearances to the mains should also be considered. These distances are outlined in the Ausgrid Network Standard, NS220 Overhead Design Manual. This document can be sourced from Ausgrid's website, www.ausgrid.com.au

Underground Cables

Safework Australia – Excavation Code of Practice, and Ausgrid's Network Standard NS156 outlines the minimum requirements for working around Ausgrid's underground cables.

Should the existing overhead or underground mains require relocating due to the minimum safety clearances being compromised in either of the above scenarios, this relocation work is generally at the developers cost.

It is also the responsibility of the developer to ensure that the existing overhead mains have sufficient clearance from all types of vehicles that are expected be entering and leaving the site.

Please do not hesitate to contact me should you require any further information.

Regards,

John O'Brien

Portfolio Manager - Design Hunter

Ausgrid

Ph: (02) 6542 9068