

6 August 2019

RMS Reference: SYD12/00072/36 and SYD12/00072/37 (A28513582)  
DP&E Reference: SSD 7628 MOD 2 and MP10\_0193 MOD 3

Director, Social and Infrastructure Assessments  
Department of Planning and Environment  
GPO Box 39  
SYDNEY NSW 2001

Attention: Dominic Crinnion / Heather Nelson

Dear Ms Harragon,

**PROPOSED CHANGES TO THE DRAINAGE SYSTEM LAYOUT AND BATTERS FOR  
STORMWATER DETENTION BASIN 9 ALONG WITH ADJUSTMENT TO THE SOUTHERN  
BOUNDARY – MOOREBANK PRECINCT EAST (MPE) STAGE 2 SSD 7628 MOD 2 AND  
MOOREBANK PRECINCT EAST CONCEPT PLAN MP 10\_0193 MOD 3 – MOOREBANK  
AVENUE, MOOREBANK**

Reference is made to your correspondence dated 16 June 2019, regarding the abovementioned Application which was referred to Roads and Maritime Services (Roads and Maritime) for comment.

Roads and Maritime has reviewed the submitted information specifically in relation to the adjustment to the southern boundary of the site to facilitate a revised drainage system layout and the remove the requirement of maximum batter slopes of 1V:4H for Stormwater Detention Basin 9 and have no objections to the proposed changes. Roads and Maritime will review the proposed change and the geotechnical investigation during detail design stage associated with the WAD attached to SSD 7628. This review will include confirmation that the proposed change was consulted with the Project Verifier (currently SMEC).

Roads and Maritime agrees to the revised wording of Condition of Consent B40(c)(iii):  
*...(iii) all on site detention basins to have maximum batter slopes of 1V:4H, with the exception of OSD 9, or, for works immediately adjacent to the Moorebank Avenue upgrade, an alternate gradient agreed to by RMS;...*

It is noted the Voluntary Planning Agreement for Moorebank Precinct West provides for the Moorebank Avenue Realignment. Roads and Maritime seeks the Department's guidance on whether the proposed boundary realignment will impact the future Moorebank Avenue Realignment.

Any inquiries in relation to this Application can be directed to Amanda Broderick on 8849 2391 or [development.sydney@rms.nsw.gov.au](mailto:development.sydney@rms.nsw.gov.au)

Yours sincerely,



Rachel Cumming  
**Senior Manager Land Use Assessment  
North West Precinct**

**Roads and Maritime Services**