



NSW RURAL FIRE SERVICE



The Secretary
Department of Planning and Environment
GPO Box 39
Sydney NSW 2001

Your reference: SSD 9039
Our reference: D18/300
DA18011811422 BB

Attention: Ellen Jones

13 July 2018

Dear Sir/Madam,

Part 3A - State Significant Development Application - Mulwala Solar Farm - Savernake Road, Mulwala

I refer to your letter dated 28 June 2018 seeking comment in relation to bush fire protection for the above Part 3A Development in accordance with section 75F (4) of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has reviewed the environmental assessment and the following conditions are recommended:

1. A Fire Management Plan (FMP) shall be prepared for the proposed facility in consultation with the local NSW RFS District Office. The FMP shall include:
 - 24 hour emergency contact details including alternative telephone contact;
 - Site infrastructure plan;
 - Fire fighting water supply plan;
 - Site access and internal road plan;
 - Construction of asset protection zones and their continued maintenance;
 - Location of hazards (physical, chemical and electrical) that will impact on the fire fighting operations and procedures to manage identified hazards during the fire fighting operations; and
 - Such additional matters as required by the NSW RFS District Office.
2. The entire solar array development footprint shall be managed as an asset protection zone as outlined within section 4.1.3 of *Planning for Bush Fire Protection, 2006* and the NSW RFS document *Standards for asset protection zones*.
3. A 10 metre defendable space, managed as an asset protection zone, shall be provided around the perimeter of the solar array development site and any proposed building to allow for emergency service personnel to undertake property protection activities.

Postal address


NSW Rural Fire Service
Planning and Environment Services
Locked Bag 17
GRANVILLE NSW 2141

T 1300 NSW RFS
F (02) 8741 5433
E records@rfs.nsw.gov.au
www.rfs.nsw.gov.au

4. A minimum 20,000 litre water supply (tank) fitted with a 65mm Storz fitting shall be located adjoining the internal property access road within the required asset protection zone.

If you have any queries regarding this advice, please contact Bradley Bourke, Development Assessment and Planning Officer, on 1300 NSW RFS.

Yours sincerely,



Martha Dotter
Acting Team Leader, Development Assessment and Planning
Planning and Environment Services (South)