

19 April 2021

Our Ref: 191069

**Chris Fraser**

Environmental Assessment Officer  
Industry Assessments  
Department of Planning, Industry & Environment  
4 Parramatta Square, Parramatta NSW 2150  
christopher.fraser@planning.nsw.gov.au

**RFI: SSD-9774 Eastern Creek Resource Recovery Facility**

Thank you for notifying Sydney Water of SSD-9774 at 21, 31, and 42 Hanson Place, Eastern Creek, which proposes construction and operation of a resource recovery facility comprising a concrete recycling plant with a processing capacity of 100,000 tonnes per year and a material storage depot with a capacity of 36,000 tonnes per year.

Sydney Water has reviewed the application based on the information supplied and provides the following comments to assist in planning the servicing needs of the proposed development.

We note that there are significant discrepancies within the proponent's supplied documentation as to their proposed water and wastewater demands. This issue is outlined in the below tables, which show the varying figures in the EIS and Water Cycle Management Plan (Appendix K).

**ENVIRONMENTAL IMPACT STATEMENT**

POTABLE WATER		WASTEWATER	
15.43 kL/day	p. 7	0.42 kL/day	p. 31
0.61 kL/day	p. 31	0.42 kL/day	p. 59
16.6 kL/day – 11.38 kL/day (inc. reuse)	p. 59	31.1 kL/day	p. 62

**APPENDIX K**

POTABLE WATER		WASTEWATER	
0.62 kL/day	p. 14	0.612 kL/day	p.15

Sydney Water request that clarification is provided as to what the correct intended average daily reticulated water demand and reticulated wastewater discharge is proposed to be.

For further liaison between DPIE and Sydney Water regarding SSD-9774, please contact Thomas Mudgway of Growth Planning at [urbangrowth@sydneywater.com.au](mailto:urbangrowth@sydneywater.com.au).

Yours sincerely,



**Kristine Leitch**

Commercial Growth Manager  
City Growth and Development, Business Development Group  
Sydney Water, 1 Smith Street, Parramatta NSW 2150