



Department of Primary Industries

OUT16/43967

Ms Susan Fox
Industry Assessments
NSW Department of Planning and Environment
GPO Box 39
SYDNEY NSW 2001

Susan.fox@planning.nsw.gov.au

Dear Ms Fox

Mayfield West Recycling Facility Extension (SSD 7698) Comment on the Environmental Impact Statement

I refer to your email of 24 October 2016 to the Department of Primary Industries (DPI) in respect to the above matter. Comment has been sought from relevant divisions of DPI. Views were also sought from NSW Department of Industry - Lands that are now a division of the broader Department and no longer within NSW DPI. Any further referrals to DPI can be sent by email to landuse.enquiries@dpi.nsw.gov.au.

DPI has reviewed the application and Environmental Impact Statement (EIS) and provides the following recommendations:

- The proponent should confirm whether the majority of the surface of the development site will be sealed with an impervious non-toxic substance and that any remaining unsealed areas will not present a risk of infiltration of surface water runoff to groundwater.
- The proponent should clarify that there will not be any adverse impact on Crown Land from the stormwater pipe outflow that drains the sedimentation basin located in the north-western corner of the development parcel. This should include confirmation that the existing infrastructure is of a suitable nature and dimension to accommodate the anticipated flow rates.

Yours sincerely

Mitchell Isaacs
Director, Planning Policy & Assessment Advice
17 November 2016

DPI appreciates your help to improve our advice to you. Please complete this three minute survey about the advice we have provided to you, here:

<https://goo.gl/o8TXWz>