

6 May 2021

**Ferdinando Macri**

Department of Planning, Infrastructure and Environment

[ferdinando.macri@dpie.nsw.gov.au](mailto:ferdinando.macri@dpie.nsw.gov.au)

**RE: SSD-10434896 The Children's Hospital at Westmead – Multi-storey Carpark**

Thank you for notifying Sydney Water of SSD-10434896 at Cnr Hawkesbury Road and Hainsworth Street, Westmead, which proposes the demolition of The Lodge and construction of a new eight level car park comprising 1000 spaces, tree removal and associated road and landscaping works. Sydney Water has reviewed the application based on the information supplied and provides the following comments to assist in planning the servicing needs of the proposed development.

**Water Servicing**

- Potable water servicing should be available via a 100mm PE watermain (laid in 2017) on Redbank Road.
- Amplifications, adjustments, and/or minor extensions may be required.

**Wastewater Servicing**

- Our servicing investigation shows that trunk wastewater infrastructure within the site can service the proposed development.

**Protection of assets:**

- Care should be taken with demolition to protect existing services. The proponent should engage with Sydney Water to ensure that adequate controls are in place to protect assets during demolition and construction.

This advice is not formal approval of our servicing requirements. Detailed requirements, including any potential extensions or amplifications, will be provided once the development is referred to Sydney Water for a Section 73 application. More information about the Section 73 application process is available on our web page in the [Land Development Manual](#).

Further advice and requirements for this proposal are in Attachment 1. If you require any further information, please contact the Growth Planning Team at [urbangrowth@sydneywater.com.au](mailto:urbangrowth@sydneywater.com.au).

Yours sincerely,



**Kristine Leitch**

Commercial Growth Manager

City Growth and Development, Business Development Group

Sydney Water, 1 Smith Street, Parramatta NSW 2150

## Attachment 1

### Sydney Water Servicing

A Section 73 Compliance Certificate under the Sydney Water Act 1994 must be obtained from Sydney Water.

The proponent is advised to make an early application for the certificate, as there may be water and wastewater pipes to be built that can take some time. This can also impact on other services and buildings, driveways or landscape designs.

Applications must be made through an authorised Water Servicing Coordinator. For help either visit [www.sydneywater.com.au](http://www.sydneywater.com.au) > Plumbing, building and developing > Developing > Land development or telephone 13 20 92.

### Building Plan Approval

The approved plans must be submitted to the Sydney Water [Tap in™](#) online service to determine whether the development will affect any Sydney Water sewer or water main, stormwater drains and/or easement, and if further requirements need to be met.

*The Sydney Water [Tap in™](#) online self-service replaces our Quick Check Agents as of 30 November 2015.*

The [Tap in™](#) service provides 24/7 access to a range of services, including:

- building plan approvals
- connection and disconnection approvals
- diagrams
- trade waste approvals
- pressure information
- water meter installations
- pressure boosting and pump approvals
- changes to an existing service or asset, e.g. relocating or moving an asset.

Sydney Water's [Tap in™](#) online service is available at:

<https://www.sydneywater.com.au/SW/plumbing-building-developing/building/sydney-water-tap-in/index.htm>