

22 August 2011



Sydney
WATER

Ms Heather Warton
Director, Metropolitan & Regional Projects North
Department of Planning & Infrastructure
GPO Box 39
Sydney NSW 2000



MP08_0227 Hornsby Ku-Ring-Gai Hospital, Mental Health Unit at 38-76 Palmerston Road, Ku-ring-gai Chase

Att: Ben Eveleigh

Dear Ms Warton,

Thank you for your letter of 21 July 2011 requesting comment on the proposed mental health unit at the above address. Sydney Water has reviewed the proposal and provides the following comments for the Department's consideration.

Water

The drinking water main available for connection is the 150mm main on the eastern side of Palmerston Road.

Wastewater

The current wastewater system has sufficient capacity to serve the proposed development. An extension of the wastewater system will be required from the 225mm main in Palmerston Road to the west of the site, which will provide a point of connection at least one metre inside the proposed lot boundaries.

Trade Waste Information

Should this development generate trade wastewater, this correspondence does not guarantee the applicant that Sydney Water will accept the trade wastewater to its sewerage system. In the event trade wastewater is generated, the property owner is required to submit an application for permission to discharge trade wastewater to the sewerage system before business activities commence. A boundary trap will be required where arrestors and special units are installed for trade waste pre-treatment.

If this development type is "Industrial" then the property may be part of sewerage catchment subject to a wastewater reuse scheme. This may impact the level of pollutants such as Total Dissolved Solids (TDS) that Sydney Water will accept from the property to the sewerage system. Businesses wishing to discharge wastewater (other than domestic sewage) should first contact a Sydney Water Trade Waste Office. A boundary trap will be required where arrestors and special units are installed for trade waste pre-treatment.

Prospective Purchasers should be made aware of the above situation under the requirements of vendor disclosure.

For further information please visit the Sydney Water website at:
<http://www.sydneywater.com.au/OurSystemsandOperations/TradeWaste/>

Sydney Water Servicing

Sydney Water will further assess the impact of any subsequent development when the developer applies for a Section 73 Certificate. This assessment will enable Sydney Water to specify any works required as a result of future development and to assess if amplification and/or changes to the system are applicable. The developer must fund any adjustments needed to Sydney Water infrastructure as a result of the development.

The developer should engage a Water Servicing Coordinator to get a Section 73 Certificate and manage the servicing aspects of the development. The Water Servicing Coordinator will ensure submitted infrastructure designs are sized and configured according to the Water Supply Code of Australia (Sydney Water Edition WSA 03-2002) and the Sewerage Code of Australia (Sydney Water Edition WSA 02-2002).

Sydney Water requests the Council to continue to instruct proponents to obtain a Section 73 Certificate from Sydney Water. Details are available from any Sydney Water Customer Centre on 13 20 92 or Sydney Water's website at www.sydneywater.com.au.

Sydney Water e-planning

Sydney Water has created a new email address for planning authorities to use to submit statutory or strategic planning documents for review. This email address is urbangrowth@sydneywater.com.au. The use of this email will help Sydney Water provide advice on planning projects faster, in line with current planning reforms. It will also reduce the amount of printed material being produced. This email should be used for:

- Section 62 consultations under the Environmental Planning and Assessment Act 1979
- consultations where Sydney Water is an adjoining land owner to a proposed development
- consultations and referrals required under any Environmental Planning Instrument
- draft LEPs, SEPPs or other planning controls, such as DCPs
- any proposed development or rezoning that will be impacted by the operation of a Sydney Water Wastewater Treatment Plant
- any proposed planning reforms or other general planning or development inquiries

If you require any further information, please contact Ainsley Rotgans of the Urban Growth Branch on 02 8849 4004 or e-mail ainsley.rotgans@sydneywater.com.au.

Yours sincerely,



for

Wayne Kennedy,
Manager of Urban Growth Strategy and Planning