



## NSW RURAL FIRE SERVICE

Department of Planning and Environment (Sydney Offices)  
GPO Box 39  
Sydney NSW 2001

Your reference: SSD 10244  
Our reference: DA20201126004471-EIS & DA  
Exhibition-1

**ATTENTION:** Dimitri Gotsis

Date: Thursday 8 July 2021

Dear Sir/Madam,

### Development Application

**State Significant – EIS & DA Exhibition – Educational Establishment**

**Edmondson Park Primary School Buchan Road Edmondson Park NSW 2174, 1//DP1257105**

I refer to your correspondence regarding the above proposal which was received by the NSW Rural Fire Service on 17/06/2021.

The NSW RFS has considered the information submitted and provides the following recommended conditions:

### Asset Protection Zones

***The intent of measures is to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants. To achieve this, the following conditions shall apply:***

1. At the commencement of building works, and in perpetuity to ensure ongoing protection from the impact of bush fires, the entire site must be managed as an Inner Protection Area (IPA) in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2 metres above the ground;
- tree canopies should be separated by 2 to 5 metres;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover;
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.
- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed.

#### Postal address

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

#### Street address

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555  
F (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)

## **Construction Standards**

***The intent of measures is to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants. To achieve this, the following conditions shall apply:***

2. New construction of the western school building must comply with Sections 3 and 5 (BAL 12.5) Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

## **Water and Utility Services**

***The intent of measures is to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building. To achieve this, the following conditions shall apply:***

3. The provision of water, electricity and gas must comply with the following in accordance with Table 6.8c of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- fire hydrant, spacing, design and sizing complies with the relevant clauses of Australian Standard AS 2419.1:2005;
- hydrants are not located within any road carriageway;
- fire hydrant flows and pressures comply with the relevant clauses of AS 2419.1:2005;
- all above-ground water service pipes are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground; and
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used.

## **Landscaping**

***The intent of measures is for landscaping. To achieve this, the following conditions shall apply:***

4. Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*. In this regard, the following principles are to be incorporated:

- A minimum 1 metre wide area, suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
- Planting is limited in the immediate vicinity of the building;
- Planting does not provide a continuous canopy to the building (i.e. trees or shrubs are isolated or located in small clusters);
- Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do not touch or overhang buildings;
- Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
- Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
- Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
- Avoid climbing species to walls and pergolas;
- Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
- Locate combustible structures such as garden sheds, pergolas and materials such as timber garden furniture away from the building; and
- Low flammability vegetation species are used.

## **Emergency and Evacuation**

***The intent of measures is to provide suitable emergency and evacuation arrangements for occupants of SFPP developments. To achieve this, the following conditions shall apply:***

5. Bush Fire Emergency Management and Evacuation Plan must be prepared consistent with the:

- The NSW RFS document: *A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan*; and,
- NSW RFS Schools Program Guide and/or Australian Standard AS 3745:2010 *Planning for emergencies in facilities*.

The Bush Fire Emergency Management and Evacuation Plan should include planning for the early relocation of occupants.

Note: A copy of the Bush Fire Emergency Management and Evacuation Plan should be provided to the Local Emergency Management Committee for its information prior to occupation of the development. An Emergency Planning Committee needs to be established to consult with residents (and their families in the case of schools) and staff in developing and implementing an Emergency Procedures Manual. Detailed plans of all emergency assembly areas including on-site and off-site arrangements - as stated in AS 3745:2010 are to be clearly displayed, and an annual emergency evacuation exercise is to be conducted.

#### **General Advice**

- Boundary fences for properties determined to be BAL 12.5 or BAL 19 may be constructed using hardwood where there is a minimum 1 metre separation from a dwelling. Where there is less than 1 metre separation or for properties determined to be BAL 29, BAL 40 or BAL FZ, non-combustible materials shall be used. No brushwood fencing shall be used.

For any queries regarding this correspondence, please contact Rohini Belapurkar on 1300 NSW RFS.

Yours sincerely,

Kalpana Varghese

**Supervisor Development Assessment & Plan  
Built & Natural Environment**