

15 May 2018



Teresa Gizzi  
NSW Department of Planning & Environment  
GPO BOX ,  
Sydney NSW 2000

570 George Street  
Sydney NSW 2000  
All mail to GPO Box 4009  
Sydney NSW 2001  
T +61 2 131 365  
[www.ausgrid.com.au](http://www.ausgrid.com.au)

**By email: [Teresa.Gizzi@planning.nsw.gov.au](mailto:Teresa.Gizzi@planning.nsw.gov.au)**

Dear Teresa,

**Development Application SSD 8636: University of Sydney Engineering and Technology Precinct Development**

We refer to the Environmental Impact Statement currently on exhibition for the above project. A review of the project documents has been undertaken in relation to potential impacts or interfaces with Ausgrid's electricity infrastructure.

In general, no objections are raised, subject to the following considerations and recommended conditions:

Prior to commencement of works within the development site, the proponent:

- i. must ensure that relevant connection applications have been made to Ausgrid for any electricity supply requirements
- ii. must ensure Ausgrid's capacity to design, construct and operate existing and future infrastructure is not impeded, including works affecting easements, duct corridors, cable routes or works that require the removal or relocation of existing infrastructure;
- iii. must confirm with Ausgrid the location and status (e.g. live, de-energised, isolated, abandoned) of existing Ausgrid infrastructure;
- iv. must liaise with Ausgrid in relation to any aspects of the development that may impact or potentially impact Ausgrid's infrastructure or ability to safely operate and maintain its infrastructure. This includes but is not limited to minimum clearances, maintaining access, impacts on structural integrity and ventilation, as well as effects of vibration, excavation and construction works;
- v. must liaise with Ausgrid to determine the relocation of any existing Ausgrid infrastructure to the satisfaction of Ausgrid in its absolute discretion; and
- vi. must liaise with Ausgrid to agree appropriate work methodologies in the vicinity of Ausgrid's infrastructure.

During works within the development site, the proponent:

- vii. must ensure that works impacting on, or in the vicinity of Ausgrid's electrical infrastructure, is undertaken in accordance with Ausgrid's standards and procedures.

Yours sincerely

A handwritten signature in dark ink, appearing to read "Jason Wall", is written over a light blue horizontal line.

Jason Wall  
Program Development Manager  
(02) 9269 7133