

From: Airport Developments
To: [Teresa Gizzi](#); [Erin White](#)
Cc: airspace.protection@casa.gov.au
Subject: AIRSERVICES RESPONSE: NSW-MA-571 - Dev, Wagga Wagga Rural Referral Hospital [SEC=UNCLASSIFIED]
Date: Tuesday, 31 July 2018 1:32:17 PM
Attachments: [image001.png](#)

Hi Teresa and Erin,

I refer to your request for an Airservices assessment of the property development for Wagga Wagga Rural Referral Hospital Redevelopment Stage 3 (SSD 9033) at the corner of Edward and Docker Streets, Wagga Wagga.

Airspace Procedures

With respect to procedures designed by Airservices in accordance with ICAO PANS-OPS and Document 9905, at a maximum height of 213.145m (700ft) AHD, the development will not affect any sector or circling altitude, nor any instrument approach or departure procedure at Wagga Wagga Airport.

Note that procedures not designed by Airservices at Wagga Wagga Airport were not considered in this assessment

Communications/Navigation/Surveillance (CNS) Facilities

This property development to a maximum height of 213.145m (700ft) AHD will not adversely impact the performance of Precision/Non-Precision Nav Aids, HF/VHF Comms, A-SMGCS, Radar, PRM, ADS-B, WAM or Satellite/Links.

Kind regards,

William Zhao

Advisor Airport Development | Operational Standards & Assurance
Airservices Australia

Phone: +61 3 9339 2504

Email: airport.developments@airservicesaustralia.com

www.airservicesaustralia.com

CAUTION: This e-mail is confidential. If you are not the intended recipient, you must not disclose or use the information contained in it. If you have received this e-mail in error, please tell us immediately by return e-mail and delete the document. Airservices Australia does not represent, warrant or guarantee that the integrity of this communication is free

From: Airport Developments
Sent: Tuesday, July 24, 2018 10:03 AM
To: Teresa Gizzi <Teresa.Gizzi@planning.nsw.gov.au>; Erin White <Erin.White@planning.nsw.gov.au>
Subject: NSW-MA-571 - Dev, Wagga Wagga Rural Referral Hospital [SEC=UNCLASSIFIED]

Hi Erin and Teresa,

I have received your proposal and commenced the Airservices assessment which will take approximately 6 weeks for completion.

If you have any questions, please contact the Airport Developments team and quote assessment code: NSW-MA-571

Please note that all completed Airservices assessments are also forwarded to CASA.

Regards,

William Zhao

Advisor Airport Development | Operational Standards & Assurance
Airservices Australia

Phone: +61 3 9339 2504

Email: airport.developments@airservicesaustralia.com

www.airservicesaustralia.com

CAUTION: This e-mail is confidential. If you are not the intended recipient, you must not disclose or use the information contained in it. If you have received this e-mail in error, please tell us immediately by return e-mail and delete the document. Airservices Australia does not represent, warrant or guarantee that the integrity of this communication is free

From: Erin White [<mailto:Erin.White@planning.nsw.gov.au>] **On Behalf Of** DPE PSVC Social and Other Infrastructure Mailbox

Sent: Monday, July 16, 2018 10:53 AM

To: Airport Developments <Airport.Developments@AirservicesAustralia.com>

Cc: Teresa Gizzi <Teresa.Gizzi@planning.nsw.gov.au>

Subject: Notice of Exhibition - Wagga Wagga Rural Referral Hospital Redevelopment Stage 3 - (SSD 9033) - Air Services Australia

Good morning

Please find attached correspondence regarding the exhibition for Wagga Wagga Rural Referral Hospital Redevelopment Stage 3 (SSD 9033) - Corner of Edward and Docker Streets, Wagga Wagga.

The public exhibition is from **Thursday 19 July 2018** until **Wednesday 15 August 2018**. The SSD Application and accompanying documents can be viewed on the department's website at <http://www.majorprojects.planning.nsw.gov.au/page/on-exhibition/>.

The Department of Planning and Environment invites you to comment on the proposal by **Wednesday 15 August 2018**.

Please send all correspondence and enquiries relating to this proposal to Teresa Gizzi who can be contacted on (02) 8275 1124 or via email at Teresa.Gizzi@planning.nsw.gov.au.

Regards

Erin White

DA Coordinator | Social and Other Infrastructure Assessments

Division of Priority Projects Assessments

320 Pitt Street | GPO Box 39 | Sydney NSW 2001

T 02 8275 1183 E Erin.White@planning.nsw.gov.au

