

**Blayney Shire Council**

Council Office 91 Adelaide Street, Blayney **Postal Address** PO Box 62, Blayney NSW 2799
Telephone (02) 6368 2104 **Facsimile** (02) 6368 3290
Email council@blayney.nsw.gov.au **Web** www.blayney.nsw.gov.au
ABN 47 619 651 511

9 June 2015

Our Ref: DB.AB.505

Senior Development & Government Affairs Manager
Infigen Energy
Level 22
56 Pitt Street
SYDNEY NSW 2000

Attn: Mr Jonthan Upson

Dear Jonathan

RE: Flyers Creek Wind Farm - Power Line

Reference is made to our recent meeting to discuss the proposed power line options currently being considered by Infigen along Errowanbang Road.

Council notes your request for Council to provide a letter of approval for the proposed transmission line, along Errowanbang Road from Panuara Road to a proposed location approximately 770m south of the Halls Road Reserve (take off into private lands).

In accordance with Section 139 of the Roads Act 1993, Council will grant consent for the erection of the power transmission line upon the route subject to the following:

- Any road crossings are at least 350mm above the minimum required clearance for the specified line voltage capacity. This is to ensure adequate safe clearance is provided for future road rehabilitation works.
- Poles are to be placed a minimum of 6m clear of the road edge (in the clear zone).
- The final location of poles shall be optimised to ensure they are located on the "inside" of curves in order to minimise the opportunity for vehicle impact.

Should the technical aspects of the line have changed, Council requests you provide it with updated information for consideration.

In relation to that section of Errowanbang Road (pink on your provided plan) in which the power line may remain within private property, Council wishes to remind Infigen Energy that it is presently preparing design plans for a major road realignment through the area. Subject to negotiations, works are programmed to be undertaken over the forthcoming two financial years, with completion expected by June 2017.

Council welcomes the opportunity to discuss the specific location of the line and associated poles as design work progresses both for the road realignment and along the existing road reserve.

Should you require further information in relation to the design of the road realignment please contact Council's Design Engineer, Mr Ian Evans, on (02) 6368 2104.

Yours sincerely

A handwritten signature in dark ink, appearing to read 'Grant Baker', with a long horizontal line extending to the right.

Grant Baker
Director Infrastructure Services