



## NSW RURAL FIRE SERVICE

Department of Planning and Environment (Sydney Offices)  
GPO Box 39  
Sydney NSW 2001

Your reference: SSI 8583

Our reference: DA20191101000785-Original-1

**ATTENTION:** May Patterson

Date: Monday 11 November 2019

Dear Sir/Madam,

**Development Application**  
**Other - Other Assessment - Electricity Generating Works**  
**Powering Sydney's Future Potts Point NSW AUS, (none)**

I refer to your correspondence regarding the above proposal which was received by the NSW Rural Fire Service on 11/10/2019.

The New South Wales Rural Fire Service (NSW RFS) provides the following recommended condition:

**Condition 1**

There shall not be any hot works (such as welding or other activities generating heat or sparks) on days of extreme or catastrophic fire danger ratings, or Total Fire Ban.

For any queries regarding this correspondence, please contact Simon Derevnin on 1300 NSW RFS.

Yours sincerely,

Kalpana Varghese  
**Team Leader, Dev. Assessment & Planning**  
**Planning and Environment Services**

**Postal address**

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

**Street address**

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

**T** (02) 8741 5555  
**F** (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)