Jasmine Tranquille

From:	UrbanGrowth <urbangrowth@sydneywater.com.au></urbangrowth@sydneywater.com.au>
Sent:	Monday, 2 March 2020 11:20 AM
To:	Jasmine Tranquille
Subject:	RE: New Catherine Field Primary School (SSD 9477) - Sydney Water
Follow Up Flag:	Follow up
Flag Status:	Completed

Dear Jasmine,

Thank you for submitting the above mentioned SSD to Sydney Water for review which proposes to construct a new primary school accommodating 1,012 students.

Sydney Water have reviewed the information supplied regarding this SSD and provide the following advice. We apologise for the delay in reply and we hope you take this advice into consideration:

Sydney Water has no objection to the proposal, however the following advice should also be taken into consideration:

Water Servicing:

• Water servicing is currently available to the site. Amplifications may be required.

Wastewater Servicing:

- Wastewater servicing is currently unavailable to this property.
- Extensions of Sydney Water assets will be required to service this property. Amplifications may also be required. Further details will be covered under the Section 73 stage.


It is recommended that the proponent engages a Water Servicing Coordinator and meetings are held between the proponent and Sydney Water to ensure that Sydney Water's requirements inform the design process.

If you require any further information, please contact the Growth Planning Team at <u>urbangrowth@sydneywater.com.au.</u>

Kind Regards,

Nicholas Geroulas Urban Growth Intelligence City Growth and Development Sydney Water, Level 13, 1 Smith Street, Parramatta NSW 2150





NOTICE: This email is confidential. If you are not the nominated recipient, please immediately delete this email, destroy all copies and inform the sender. Sydney Water Corporation (Sydney Water) prohibits the unauthorised copying or distribution of this email. This email does not necessarily express the views of Sydney Water. Sydney Water does not warrant nor guarantee that this email communication is free from errors, virus, interception or interference.