

From: [Jessica Fountain](#)
To: [David Glasgow](#)
Subject: FW: Notice of Exhibition – Towers 2A and 2B Australia Ave Sydney Olympic Park (SSD-9383)
Date: Friday, 13 December 2019 3:22:17 PM
Attachments: [image001.png](#)

Jess Fountain
DA Coordinator

Key Sites and Industry Assessments | Department of Planning, Industry and Environment

T 02 9860 1559 | E Jessica.fountain@planning.nsw.gov.au

Level 29, 320 Pitt Street, Sydney | GPO Box 39, Sydney NSW 2001

www.dpie.nsw.gov.au



**Planning,
Industry &
Environment**

The Department of Planning, Industry and Environment acknowledges that it stands on Aboriginal land. We acknowledge the traditional custodians of the land and we show our respect for elders past, present and emerging through thoughtful and collaborative approaches to our work, seeking to demonstrate our ongoing commitment to providing places in which Aboriginal people are included socially, culturally and economically.



Please consider the environment before printing this e-mail.

From: Tharindu Herath <tharindu.herath@ausgrid.com.au>
Sent: Friday, 13 December 2019 3:20 PM
To: Jessica Fountain <Jessica.Fountain@planning.nsw.gov.au>
Cc: Paul Nakhle <pnakhle@ausgrid.com.au>; Development/Ausgrid <development@ausgrid.com.au>; Lila Shi <lila.shi@ausgrid.com.au>
Subject: Notice of Exhibition – Towers 2A and 2B Australia Ave Sydney Olympic Park (SSD-9383)

Hi Jessica,

Ausgrid has reviewed the EIS and in particular Appendix CC – Electrical Services Overview Report-Site 2 V2 and Appendix CC Electrical Services Statement of Design Intent.

Before any construction, it should be noted that there are:

- In-service 11kV High Voltage UG Feeders within a conduit that run alongside Australia Avenue, alongside Parkview Drive, and under Murray Rose Avenue
- Out-of-service 11kV High Voltage UG Feeders that run alongside Murray Rose Avenue
- In-service 415V Low Voltage UG cables that run along Australia Avenue and Parkview Drive

Dial Before You Dig (DBYD) should be contacted before any construction is done.

We recommend the proponent make a connection application to Ausgrid as soon as practicable.

Kind Regards,

Tharindu Herath

API NSW Vacation Placement Student – Asset Protection | Transmission Services | Technical Operations



Email: tharindu.herath@ausgrid.com.au

First Floor, Building 2, 25-27 Pomeroy Street, Homebush, NSW, 2140

Please consider the environment before printing this email

This e-mail may contain confidential or privileged information. If you have received it in error, please notify the sender immediately via return e-mail and then delete the original e-mail. If you are the intended recipient, please note the change of sender email address to @ausgrid.com.au. Ausgrid has collected your business contact details for dealing with you in your business capacity. More information about how we handle your personal information, including your right of access is contained at <http://www.ausgrid.com.au/>