



NSW RURAL FIRE SERVICE



The Secretary
Department of Planning & Environment
GPO Box 39
Sydney NSW 2001

Your reference: DA 374-11-00 Mod 4
Our reference: D17/3801

19 December 2017

Attention: Rose-Anne Hawkeswood

Dear Sir/Madam,

Exhibition – Sunrise Mine (formerly Syerston Mine) Mod 4

Reference is made to correspondence dated 28 December 2017 seeking comments on the Environmental Assessment prepared in relation to the above modification application in accordance with the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has reviewed the information provided and advises that it has no objection subject to the following recommended conditions:

- A Fire Management Plan (FMP) shall be prepared in consultation with the local NSW RFS Fire Control Centre. The FMP shall include:
 - 24 hour emergency contact details including alternative telephone contact;
 - Site infrastructure plan;
 - Fire fighting water supply plan;
 - Site access and internal road plan;
 - Management of stockpile areas on the site such that they do not represent a bush fire hazard;
 - Construction of Asset Protection Zones (APZ) and their continued maintenance;
 - Location of hazards (Physical, Chemical and Electrical) that will impact on fire fighting operations and procedures to manage identified hazards during fire fighting operations;
 - Such additional matters as required by the NSW RFS District Office (FMP review and updates).
- A 20 metre defendable space shall be provided between operational areas and the surrounding bush fire hazard. This shall be managed as an Asset Protection Zone as outlined within section 4.1.3 and Appendix 5 of *Planning for Bush Fire Protection 2006* and the NSW Rural Fire Service's document *Standards for Asset Protection Zones*.
- A 65mm storz fitting shall be provided to water supply point(s) in a location(s) agreed in the FMP.

Postal address

NSW Rural Fire Service
Records Management
Locked Bag 17
GRANVILLE NSW 2141

Street address

NSW Rural Fire Service
Planning and Environment Services (East)
42 Lamb Street
GLENDENNING NSW 2761

T 1300 NSW RFS
F (02) 8741 5433
E pes@rfs.nsw.gov.au
www.rfs.nsw.gov.au

If you have any queries regarding this advice, please contact Development Assessment and Planning on 1300 NSW RFS.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Nika', followed by a long horizontal flourish.

Nika Fomin
Manager, Planning and Environment Services (East)