



OUT20/3735

Prity Cleary  
Planning & Assessment Group  
NSW Department of Planning, Industry and Environment

[Prity.Cleary@planning.nsw.gov.au](mailto:Prity.Cleary@planning.nsw.gov.au)

Dear Prity

**Westmead Catholic Community Education Campus (SSD 10383  
Environmental Impact Statement**

I refer to your email of 1 April 2020 to the Department of Planning, Industry and Environment (DPIE) Water and the Natural Resources Access Regulator (NRAR) about the above matter.

The following recommendations are provided by DPIE Water and NRAR. Please note Crown Lands, the Department of Primary Industries (DPI) – Fisheries and DPI - Agriculture all now provide a separate response directly to you.

Prior to Approval

- The proponent should identify the water source and quantity required for the construction and operation of the development.
- The proponent must obtain a Water Access Licence should the project be required to dewater 3 megalitres or greater of groundwater per year, in accordance with the *Water Management (General) Regulation 2018*.

Any further referrals to DPIE – NRAR & Water can be sent by email to:  
[landuse.enquiries@dpi.nsw.gov.au](mailto:landuse.enquiries@dpi.nsw.gov.au).

Any further referrals to (a) Crown Lands; (b) DPI – Fisheries; and (c) DPI – Agriculture can be sent by email to: (a) [lands.ministerials@industry.nsw.gov.au](mailto:lands.ministerials@industry.nsw.gov.au);  
(b) [ahp.central@dpi.nsw.gov.au](mailto:ahp.central@dpi.nsw.gov.au); and (c) [landuse.ag@dpi.nsw.gov.au](mailto:landuse.ag@dpi.nsw.gov.au) respectively.

Yours sincerely

Simon Francis  
Senior Project Officer, Assessments  
**Water – Strategic Relations**  
20 May 2020