



Department of
Primary Industries

OUT15/31131

Mr Matthew Rosel
Metropolitan Projects
NSW Department of Planning and Environment
GPO Box 39
SYDNEY NSW 2001

Matthew.Rosel@planning.nsw.gov.au

Dear Mr Rosel,

**Crown Sydney Hotel Resort, Barangaroo (SSD_6957)
Comment on the Response to Submissions Report**

I refer to your email dated 21 October 2015 to the Department of Primary Industries in respect to the above matter.

Comment by DPI Water

DPI Water has reviewed the Response to Submissions (RTS) and provides the following comments:

DPI Water notes groundwater seepage into the basement is based on a design criterion rather than a field based assessment and recommends the RTS is amended to state this for clarification.

For further information please contact Janne Grose, Water Regulation Officer (Parramatta Office) on 8838 7505 or at janne.grose@dpi.nsw.gov.au.

Yours sincerely

A handwritten signature in blue ink, appearing to read 'M Isaacs'.

Mitchell Isaacs
Director, Planning Policy & Assessment Advice
6/11/2015