

From: UrbanGrowth
Sent: Friday, 11 January 2013 10:34 AM
To: 'Kate MacDonald'
Subject: RE: MP 11_0002 & SSD 12_5374 - Barangaroo Central

Hi Kate,

Thank you for your correspondence of 19 December 2012 requesting comment on the proposed works on the Waterfront Promenade and Public Domain, at Barangaroo Central. Sydney Water has reviewed the proposal and provides the following comments for the Department's consideration.

Trade Waste Information

Should this development generate trade wastewater, this correspondence does not guarantee the applicant that Sydney Water will accept the trade wastewater to its sewerage system. In the event trade wastewater is generated, the property owner is required to submit an application for permission to discharge trade wastewater to the sewerage system before business activities commence. A boundary trap will be required where arrestors and special units are installed for trade waste pre-treatment.

For further information please visit the Sydney Water website at:
<http://www.sydneywater.com.au/OurSystemsandOperations/TradeWaste/>

Regards

Corrine Manyweathers | **Student Town Planner**

Urban Growth Strategy | Sydney Water
Level 6, 1 Smith Street Parramatta NSW 2150
PO Box 399 Parramatta NSW 2124
T 8849 4014

corrine.manyweathers@sydneywater.com.au | sydneywater.com.au