

18 April 2013



Sydney
WATER

Ashley Cheong
Planner
Department of Planning & Infrastructure
GPO Box 39
SYDNEY NSW 2001



SSD4964 – Waste Recycling Project - 37 Grand Avenue, Camellia

Dear Ashley Cheong,

Thank you for requesting comment on the proposed Materials Recycling Facility at the above address. Sydney Water has reviewed the proposal and we request that the Department includes the following conditions in the development consent.

Contamination

This site and or adjacent sites are recognised as having soil and groundwater contaminated with chromium (VI). It is the proponent's responsibility to make enquiries through the Environmental Protection Authority (EPA) and take all appropriate precautions to manage contamination issues.

Trade Waste Information

Should this development generate trade wastewater, this correspondence does not guarantee the applicant that Sydney Water will accept the trade wastewater to its sewerage system. In the event trade wastewater is generated, the property owner is required to submit an application for permission to discharge trade wastewater to the sewerage system before business activities commence. A boundary trap will be required where arrestors and special units are installed for trade waste pre-treatment.

If this development type is "Industrial" then the property may be part of sewerage catchment subject to a wastewater reuse scheme. This may impact the level of pollutants such as Total Dissolved Solids (TDS) that Sydney Water will accept from the property to the sewerage system. Businesses wishing to discharge wastewater (other than domestic sewage) should first contact a Sydney Water Trade Waste Office. A boundary trap will be required where arrestors and special units are installed for trade waste pre-treatment.

Prospective Purchasers should be made aware of the above situation under the requirements of vendor disclosure.

For further information please visit the Sydney Water website at:
<http://www.sydneywater.com.au/OurSystemsandOperations/TradeWaste/>

Sydney Water Servicing


Sydney Water will further assess the impact of any subsequent development when the developer applies for a Section 73 Certificate. This assessment will enable Sydney Water to specify any works required as a result of future development and to assess if amplification and/or changes to the system are applicable. The developer must fund any adjustments needed to Sydney Water infrastructure as a result of the development.

The developer should engage a Water Servicing Coordinator to get a Section 73 Certificate and manage the servicing aspects of the development. The Water Servicing Coordinator will ensure submitted infrastructure designs are sized and configured according to the Water Supply Code of Australia (Sydney Water Edition WSA 03-2002) and the Sewerage Code of Australia (Sydney Water Edition WSA 02-2002).

Sydney Water requests the Council to continue to instruct proponents to obtain a Section 73 Certificate from Sydney Water. Details are available from any Sydney Water Customer Centre on 13 20 92 or Sydney Water's website at www.sydneywater.com.au.

If you require any further information, please contact Corrine Manyweathers of the Urban Growth Branch on 02 8849 4014 or e-mail corrine.manyweathers@sydneywater.com.au.

Yours sincerely,



Adrian Miller,
Manager, Growth Strategy