From:	Jason Lu
To:	Andrew Worboys; Clinton Jurd; Necola Chisholm
Subject:	RE: Minchinbury Employment Estate Warehousing and Distribution Park
Date:	Tuesday, 15 September 2015 4:20:06 PM
Attachments:	image001.png

Hi Necola

Endeavour Energy has no objections to the development proposal.

There is zone substation capacity to supply the new load from Huntingwood ZS and the developer will need to make arrangements for 11kV connection works via our Network Connections.

Regards Jason

Jason Lu Capacity Planning Manager Asset and Network Planning Endeavour Energy D: (02) 9853 5003 M: 0403 604 607 T: 131 081 E: jason.lu@endeavourenergy.com.au 51 Huntingwood Drive, Huntingwood NSW 2148 www.endeavourenergy.com.au