



File Ref. No: FRN22/1382 BFS22/2010 8000021065
TRIM Doc. No: D22/37974
Contact: Senior Firefighter Michael Millar

12 May 2022

BRUCE ZHANG
NSW Department of Planning and Environment
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Bruce,

Re: Advice on Environmental Impact Statement (EIS) – DHL WAREHOUSE AND DISTRIBUTION CENTRE (SSD-36156297) (Fairfield City).

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on the 10 May 2022, requesting advice on the EIS for DHL WAREHOUSE AND DISTRIBUTION CENTRE (SSD-36156297). FRNSW have reviewed the EIS along with the Preliminary Hazards Analysis (PHA).

Given the size and complexity of the proposed facility, and to ensure first responders have information readily available to render safe any incident, FRNSW make the following recommendations:

1. That an Emergency Response Plan (ERP) is developed for the site in accordance with HIPAP No.1.¹
2. That an Emergency Services Information Package (ESIP) be prepared in accordance with FRNSW fire safety guideline – Emergency services information package and tactical fire plans.²

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS22/2010. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Yours sincerely,



Superintendent John Hawes
Manager
Operational Liaison Special Hazards Unit

Cc: bruce.zhang@planning.nsw.gov.au

¹ <https://www.planning.nsw.gov.au/-/media/Files/DPE/Other/hazardous-industry-planning-advisory-paper-no-1-emergency-planning-2011-01.pdf?la=en>

² https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/guidelines_ESIP_and_TFP.pdf