

8 November 2017

Our Ref: 167597

Dominic Crinnion
Acting Director
Social & Other Infrastructure Assessments
Department of Planning & Environment
GPO Box 39 Sydney,
NSW 2001

**RE: 120-126 Hezlett Road, Kellyville (SSD8344)
North Kellyville Public School**

Dear Dominic,

Thank you for notifying Sydney Water of the development application listed above. We have reviewed the application and provide the following information to assist in planning the servicing needs of the development, based on the information supplied.

Water

- The development site is located within Kellyville Elevated Water Supply Zone.
- Strategic investigation shows that the trunk water systems have adequate capacity to service the proposed school accommodating 1,000 students.

Wastewater

- The proposed development is located within the Rouse Hill Sewerage System.
- There is sufficient trunk and treatment capacity to service the proposed development.

Recycled Water

- The development site is within Kellyville Recycled Water Supply Zone.
- This system has sufficient capacity to supply recycled water for irrigation and toilet flushing purposes.

This advice is not a formal approval of our servicing requirements. Formal requirements for servicing the development will be determined as part of the Section 73 application. More information about the Section 73 application process is available on our web page in the [Land Development Manual](#).

Sydney Water E-Planning

Sydney Water has an email address for planning authorities to submit statutory or strategic planning documents for review. This email address is urbangrowth@sydneywater.com.au.

Further advice and requirements for this proposal are in the Attachment 1 and 2. If you require any further information, please contact Lulu Huang of Growth Planning and Development on 02 8849 4269 or email lulu.huang@sydneywater.com.au.

Yours sincerely,



Paul Mulley
Manager, Growth Planning & Development

Attachment 1

Sydney Water Servicing

A Section 73 Compliance Certificate under the Sydney Water Act 1994 must be obtained from Sydney Water prior to development commencement. It is recommended that the Council includes this term as a condition of the DA approval.

The proponent is advised to make an early application for the certificate, as there may be water and wastewater pipes to be built that can take some time. This can also impact on other services and buildings, driveways or landscape designs.

Applications must be made through an authorised Water Servicing Coordinator. For help either visit www.sydneywater.com.au > Plumbing, building and developing > Developing > Land development or telephone 13 20 92.

Building Plan Approval

The developer must have the building plans stamped and approved before any construction is commenced. Approval is needed because construction/building works may affect Sydney Water's assets (e.g. Water, sewer and stormwater mains).

For further assistance please telephone 13 20 92 or refer to the Building over or next to assets page on the Sydney Water website (see Plumbing, building and developing then Building over or next to assets).

Attachment 2

Requirements for Business Customers for Commercial and Industrial Property Developments

If this property is to be developed for Industrial or Commercial operations, it may need to meet the following requirements:

Trade Wastewater Requirements

If this development is going to generate trade wastewater, the property owner must submit an application requesting permission to discharge trade wastewater to Sydney Water's sewerage system. You must wait for approval of this permit before any business activities can commence.

The permit application should be emailed to Sydney Water's Business Customer Services at businesscustomers@sydneywater.com.au

It is illegal to discharge Trade Wastewater into the Sydney Water sewerage system without permission.

A Boundary Trap is required for all developments that discharge trade wastewater where arrestors and special units are installed for trade wastewater pre-treatment.

If the property development is for Industrial operations, the wastewater may discharge into a sewerage area that is subject to wastewater reuse. Find out from Business Customer Services if this is applicable to your development.

Backflow Prevention Requirements

Backflow is when there is unintentional flow of water in the wrong direction from a potentially polluted source into the drinking water supply.

All properties connected to Sydney Water's supply must install a testable Backflow Prevention Containment Device appropriate to the property's hazard rating. Property with a high or medium hazard rating must have the backflow prevention containment device tested annually. Properties identified as having a low hazard rating must install a non-testable device, as a minimum.

Separate hydrant and sprinkler fire services on non-residential properties, require the installation of a testable double check detector assembly. The device is to be located at the boundary of the property.

Before you install a backflow prevention device:

1. Get your hydraulic consultant or plumber to check the available water pressure versus the property's required pressure and flow requirements.
2. Conduct a site assessment to confirm the hazard rating of the property and its services. Contact PIAS at NSW Fair Trading on 1300 889 099.