
Sent: Monday, 29 October 2018 8:56 AM

To: Luisa Maguire <Luisa.Maguire@planning.nsw.gov.au>; Airspace Protection <AirspaceProtection@syd.com.au>

Cc: Annie Leung <Annie.Leung@planning.nsw.gov.au>

Subject: RE: 17/0469b Electronic notification for Notice of Exhibition for Martin Place Station Precinct Stage 2 – South Site (SSD 9326) and Martin Place Station Precinct Stage 2 – North Site (SSD 9270)

Good morning Annie & Luisa,

Sydney Airport have reviewed the amended plans and can advise the following:

17/0454a - SSD 9326 - MARTIN PLACE PRECINCT SOUTH SITE – 152.4m AHD - below the Obstacle Limitation Surface (OLS) of 156m AHD – approved by Sydney Airport.

17/0469 – SSD 9270 - MARTIN PLACE PRECINCT NORTH SITE – 194m AHD - penetrates the OLS of 156m AHD – approved by Federal Department of Infrastructure & Regional Development (DIRD) to a height of 214.2m AHD

Kind regards
Maryann

Maryann Loraine-Grews

Airspace Protection Approvals Coordinator
Sydney Airport

AirspaceProtection@syd.com.au
www.sydneyairport.com.au



Proudly Airport Carbon Accredited

