

ADG Key Criteria - 1 Bedroom Apartments

Apartment Type	Number of Apartments % of Apartment Type	Minimum Apartment Size (m2)	Minimum Minimum Balcony Area (m2)	Minimum Minimum Balcony Depth (m)	Master Bed Area (m2)	Additional Bed Area (m2)	Minimum Bed Dimension (m)	Maximum Habitable Room Depth (m)	Minimum Living Room Width (m)	Minimum Internal Storage (m3)	Minimum External Storage (m3)	Minimum 12 Hours Solar 9AM-3PM (Hours)	Any Solar 9AM-3PM (Hours)	Cross Ventilation (Min 60% L1-L9)	Minimum Floor to Ceiling Height (m)	Consistency
ADG Criteria:		50	8	2	10	9	3	8	3.6	3	3	2:00	0:00	Deemed	2.7	
PO502 & LA502	15	62.5	8.9	2.5	13.2	N/A	3.1	7.8	4.5	5.2	0.8	0:00	1:30	No	2.7	13/14
Consistent	15%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	Achieves Intent	YES	YES	YES	93%
MA502 & LO502	3	62.5	8.9	2.5	13	N/A	3.1	7.8	4.5	5.2	0.8	2:15	2:15	Deemed	2.7	13/14
Consistent	3%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	93%
UA502	8	64.1	8.9	2.5	13	N/A	3.1	7.8	4.5	4.3	1.7	2:15	2:15	Deemed	2.7	13/14
Consistent	8%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	93%
PO503 & LA503	15	53.1	8.9	2.5	13	N/A	3.1	6.2	4.5	6.8	0	0:00	1:00	Mech Plenum	2.7	13/14
Consistent	15%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	Achieves Intent	YES	YES	YES	93%
MA503 & LO503	3	53.1	8.9	2.5	13	N/A	3.1	6.2	4.5	6.8	0	2:00	2:00	Deemed	2.7	14/14
Consistent	3%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	100%
UA503	8	53.4	8.9	2.5	13	N/A	3.1	6.3	4.5	5	1	2:00	2:00	Deemed	2.7	14/14
Consistent	8%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	100%
PO504	1	56.7	9	2.5	13.3	N/A	3.1	6.3	4.5	6	0	0:00	1:00	Mech Plenum	2.7	13/14
Consistent	1%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	Achieves Intent	YES	YES	YES	93%
LA504	14	52.2	9	2.5	15.4	N/A	3.5	4.3	4.5	6	-	0:00	1:15	YES	2.7	13/14
Consistent	14%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	Achieves Intent	YES	YES	YES	93%
MA504	2	60.6	9	2.5	17	N/A	3.5	5.8	4.5	6	-	2:00	2:15	Deemed	2.7	14/14
Consistent	2%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	100%
LO504 & UA504	9	55.3 - 61.1	9	2.5	17	N/A	3.5	5.8 - 5.1	4.4 - 4.5	3.1 - 4.8	2.9 - 1.2	2:00	2:15	Deemed	2.7	14/14
Consistent	9%	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	100%
LA507, MA507, LO507 & UA507	25	54	8.6	2.4	12.9	N/A	3	8.2	3.4	3.3	2.7	4:45	4:45	NO	2.7	12/14
Consistent	24%	YES	YES	YES	YES	YES	YES	Achieves Intent	Achieves Intent	YES	YES	YES	YES	YES	YES	86%

TOTAL 1 BEDROOMS	103
-------------------------	------------

ADG Key Criteria - 2 Bedroom Apartments

[illegible]

ADG Key Criteria - 3 Bedroom Apartments

[illegible]

TOTAL 3 BEDROOMS	29
-------------------------	-----------

ADG Key Criteria - 4 Bedroom Apartments

[illegible]