

Scott Hay

From: Jason Wall <jwall@ausgrid.com.au>
Sent: Tuesday, 19 February 2019 2:12 PM
To: Scott Hay
Cc: Development/Ausgrid; Tim Knight; Paul Nakhle; Property; Keiran Fleming
Subject: HPE CM: RE: Notice of exhibition - Kyeemagh Public School (SSD 9391) - Ausgrid

Follow Up Flag: Follow up
Flag Status: Completed

Hi Scott,

We note the proponent has contacted Ausgrid to determine that a new substation is required for the development (Per Section 5.6 of the EIS).

Ausgrid also has 132,000V underground cables present in Jacobson Ave and recommends the proponent obtain the plans through DBYD and refer to Ausgrid Network Standard NS156 regarding working near these cables. We note the proposed mains water connection will need to cross these cables and suitable construction arrangements will need to be in place to enable this to be completed safely.

Thanks,

Jason Wall
Program Development Manager
(02) 9269 7133