

20 May 2019



Mr Patrick Copas
Planning Officer
NSW Planning & Environment
GPO Box 39
Sydney NSW 2001

570 George Street
Sydney NSW 2000
All mail to GPO Box 4009
Sydney NSW 2001
T +61 2 131 365
www.ausgrid.com.au

patrick.copas@planning.nsw.gov.au

Mr Copas,

Re: Notice of Exhibition of the Lane Cove West Data Centre (SSD 9741)

Ausgrid notes that the proponent has not directly responded to Ausgrid's submission in the Request for SEARs regarding the provision of access to Ausgrid's Transmission Line easement on the subject property.

Ausgrid recommends that the conditions of consent include a requirement for consultation with Ausgrid to establish a right of way in the proposed development for access to Ausgrid's easement (DP641935) at the rear of the block. The right of way is to be compliant with the relevant Ausgrid network standards.

An earthing assessment and appropriate design of the proposed boundary fence that traverses Ausgrid's Transmission Line easement is also required. If the fence is of metallic construction, it must be earthed to AS/NZ standards.

Yours sincerely,

A handwritten signature in black ink, appearing to read "Jason Wall", with a stylized, flowing script.

Jason Wall
Program Development Manager
Ph: (02) 9269 7133