

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]



Planning,
Industry &
Environment

[REDACTED]

From: Bernard Daly <Bernard.Daly@fire.nsw.gov.au>

Sent: Tuesday, 13 October 2020 12:27 PM

To: Jessica Fountain <Jessica.Fountain@planning.nsw.gov.au>

Cc: Fire Safety <FireSafety@fire.nsw.gov.au>

Subject: HPE CM: Response to Environmental Impact Statement (EIS) exhibition for Cleanaway's Western Sydney Energy and Resource Recovery Centre (SSD-10395). BFS20/3086

Cleanaway's Western Sydney Energy & Resource Recovery Centre (SSD-10395) EIS Exhibition

Dear Jess,

I refer to the submission of the request for agency comment on the Environmental Impact Statement (EIS), dated 1 October 2020, for the above development. The relevant parts of the proponent's EIS have been reviewed and the following comments are submitted for consideration.

It is highlighted that the Fire and Rescue NSW Act 1989 (the Act) imposes specific statutory functions and duties upon the Commissioner of FRNSW. Clause 5A of the Act requires the Commissioner to take all practicable measures for preventing and extinguishing fires and protecting and saving life and property within a FRNSW fire district. Clause 5A of the Act also requires the Commissioner to protect and save life and property endangered by hazmat incidents and for confining a hazmat incident and for rendering the hazmat site safe.

In addition, the Work Health and Safety (WHS) Act 2011 (and its subordinate Regulation) classify FRNSW as a person (entity) conducting a business or undertaking (PCBU). Clauses 34 and 35 of the WHS Regulation impose specific obligations upon a PCBU to identify hazards and manage risks at workplaces. A site involved in fire or hazmat incident is deemed to be a FRNSW place of work.

Due to the fire hazards associated with waste recovery facilities, and the potential risk to the health and safety of firefighters, both FRNSW and the NSW Rural Fire Service must be able to implement effective and appropriate risk control measures when managing an emergency incident at the proposed site.

In the event of a fire or hazardous material incident, it is important that first responders have ready access to information which enables effective hazard control measures to be quickly implemented. Without limiting the scope of the emergency response plan (ERP) requirements of Clause 43 of the Work Health and Safety Regulation 2017 (the Regulation), the following matters are recommended to be addressed:

1. That a comprehensive ERP is developed for the site.
2. That the ERP specifically addresses foreseeable on-site and off-site fire events and other emergency incidents (such as dust explosions, bushfires in the immediate vicinity) or potential hazmat incidents.
3. That the ERP details the appropriate risk control measures that would need to be implemented to safely mitigate potential risks to the health and safety of firefighters and other first responders.

Such measures will include the level of personal protective clothing required to be worn, the minimum level of respiratory protection required, decontamination procedures to be instigated, minimum evacuation zone distances and a safe method of shutting down and isolating plant and equipment.

4. Other risk control measures that may need to be implemented in a fire emergency (due to any unique hazards specific to the site) should also be included in the ERP.
5. That two copies of the ERP (detailed in recommendation 1 above) be stored in a prominent 'Emergency Information Cabinet' located in a position directly adjacent to the site's main entry point/s.
6. Once constructed and prior to operation, that the operator of the facility contacts the relevant local emergency management committee (LEMC). The LEMC is a committee established by Section 28 of the State Emergency and Rescue Management Act 1989. LEMCs are required to be established so that emergency services organisations and other government and non-government agencies can proactively develop comprehensive inter agency local emergency procedures for significant hazardous sites within their local government area. The contact details of members of the LEMC can be obtained from the relevant local council.

For further information please contact the Fire Safety Infrastructure Liaison Unit, referencing FRNSW file number BFS20/3086. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Regards,



SF BERNARD DALY
Fire Investigation & Research Officer

T: (02) 9742 7395 M: 0439 810 575
E: Bernard.Daly@fire.nsw.gov.au
1 AMARINA AVENUE GREENACRE NSW 2190
www.fire.nsw.gov.au

FRNSW CONFIDENTIALITY NOTICE AND DISCLAIMER

The information in this transmission may be confidential and/or protected by legal professional privilege, and is intended only for the person or persons to whom it is addressed. If you are not the intended recipient of this message you must not read, forward, print, copy, disclose, use or store in any way the information in this e-mail or any attachment it may contain. Please notify the sender immediately and delete or destroy all copies of this e-mail and any attachment it may contain.

Views expressed in the message are those of the individual sender, and are not necessarily the views of Fire and Rescue NSW (FRNSW). Use of electronic mail is subject to FRNSW policy and guidelines. FRNSW reserves the right to filter, inspect, copy, store and disclose the contents of electronic mail messages, as authorised by law.

This message has been scanned for viruses.
