

Modification of Approval

Section 75W of the *Environmental Planning and Assessment Act 1979*

I, the Director Infrastructure Projects, in accordance with the Instrument of Delegation issued by the Minister for Planning, on 25 January 2010, pursuant to section 75W of the *Environmental Planning and Assessment Act 1979* determine the modification to the approval referred to in Schedule 1 in the manner set out in Schedule 2.



Scott Jeffries
Director Infrastructure Projects
as delegate for the Minister for Planning

Sydney, 1 April 2010

MP 07_0121 MOD 1

SCHEDULE 1

Project Approval:

granted by the Minister for Planning on 1 June 2009 (MP 07_021).

For the following:

Construction and operation of the Camellia and Rosehill Recycled Water Scheme (also known as the Rosehill Recycled Water Scheme). The project involves the construction and operation of the following key components:

1. construction and operation of a recycled water treatment plant (RWTP), pumping station, water storage tanks and other equipment at North Street, Fairfield;
2. a connection to the existing Liverpool to Ashfield pipeline (the source of feed effluent for the recycled water treatment process);
3. a distribution system, including:
 - an elevated storage reservoir at Woodville Golf Course, Barbers Road, Guildford;
 - two surface reservoirs and one pumping station on the south-east corner of Durham Street and Grand Avenue, Rosehill; and
 - a distribution pipeline approximately 20 kilometres long.

Modification:

Amendment to condition 1.1 to reflect a six part modification involving: a route realignment of the recycled water pipeline, an increase in transformer size at the Fairfield RWTP, a minor modification to the

wording of condition 2.37 regarding surface height limits at the RWTP, details of the alignment of a sewer connection pipeline between the RWTP and the sewer main, an increase in the height of the Woodville reservoir storage tank, and changes to the tank configuration at the Rosehill Reservoir. As a consequence, amendments have also been made to condition 1.2.

SCHEDULE 2

The approval is modified as follows:

1. Replacing existing condition 1.1 with new condition 1.1 as follows:

- 1.1 The Proponent shall carry out the project generally in accordance with the:
- Major Project Application 07_0121;
 - Rosehill recycled Water Scheme, Environmental Assessment, prepared by Parsons Brinckerhoff and dated January 2009;
 - Camellia and Rosehill Recycled Water Scheme Preferred Project Report, prepared by Jemena Asset Management and dated 19 March 2009; and
 - Environmental Assessment of the Modification to the Rosehill Recycled Water Project, prepared by Jemena Asset Management and dated 19 March 2009 and supplementary letter to the Department of Planning from Parsons Brinckerhoff Australia Pty Ltd regarding commitments at Woodville reservoir dated 30 March 2010; and
 - the conditions of this approval.

2. Replacing existing condition 1.2 with new condition 1.2 as follows:

- 1.2 In the event of an inconsistency between:
- the conditions of this approval and any document listed from condition 1.1a) to 1.1d) inclusive, the conditions of this approval shall prevail to the extent of the inconsistency; and
 - any document listed from condition 1.1a) to 1.1d) inclusive, and any other document listed from 1.1a) to 1.1d) inclusive, the most recent document shall prevail to the extent of the inconsistency.

3. Replacing existing condition 2.37 with new condition 2.37 as follows:

- 2.37 The Proponent is permitted to construct surface facilities and associated infrastructure at the recycled water treatment plant generally located and configured consistent with the preliminary designs presented in the documents referred to in condition 1.1 of this approval and in particular, Figure 2.1 of the document referred to under condition 1.1c). Heights of surface facilities will be limited as specified in Table 1.

Table 1 – Maximum Height of Surface Facilities

Item	Height Limit (m AHD)	Height Limit (including any access ladders, safety rails, roof ventilation apparatus)
Recycled Water Storage Tank	15.1	16.3
Feed Balance Tank	14.7	16.0
Detention Tank	14.9	16.2
Filtration (Reverse Osmosis) Building	17.1	18.4
Degasser	15.9	17.2
Flocculation Tank	13.5	14.7
Reverse Osmosis Tank	13.6	14.9
Reverse Osmosis Permeate Collection Tank	12.0	13.2