



- SEDIMENT CONTROL POND NOTES:**
1. TYPE D BASIN IS REQUIRED
 2. VOLUME OF TYPE D POND SHALL BE AS NOMINATED ON DRAWING DA20. NOMINAL POND LOCATIONS AND NOMINAL DIMENSIONS.
 3. SEDIMENT BUILD UP TO NOT EXCEED 33% TOTAL CAPACITY OF POND.
 4. WATER LEVEL TO BE MAINTAINED AT 20% CAPACITY DURING SETTLING PERIOD.
 5. LENGTH TO WIDTH RATIO TO BE 3:1 MIN. TYPICAL DEPTH TO BE 15m.
 6. PROVIDE SECURITY FENCE TO POND FOR SAFETY.
 7. DEWATERING OF POND TO BE PERFORMED TO THE BOTTOM OF THE SEDIMENT SETTLING ZONE FOLLOWING ACHIEVEMENT OF WQO's. MANAGEMENT OF DOSAGE AND DISCHARGE TO BE ACHIEVED IN A TIMELY MANNER BEFORE THE NEXT RAIN EVENT AND WITHIN 5 DAYS OF THE INITIAL RAINFALL EVENT.
 8. WATER TO BE DOSED WITH GYPSUM TO ACCELERATE SETTLEMENT OF SUSPENDED SOLIDS.
 9. GYPSUM DOSAGE RATE TO BE APPLIED AT APPROX. 32kg PER 100 CUBIC METRE OF COLLECTED RUNOFF.
 10. THE USE OF ALUM AS A FLOCCULANT IS NOT RECOMMENDED AND IS TO BE USED ONLY FOLLOWING CONSULTATION WITH AND ACCEPTANCE FROM GOLD COAST CITY COUNCIL ESC OFFICERS.
 11. DISCHARGE FROM POND IS PERMISSIBLE WHEN THE WATER PH IS 6.5-8.5 AND IS CLARIFIED TO AT OR BELOW A TSS OF 50mg/L (75 NTU). CLARIFICATION WOULD GENERALLY BE ACHIEVED IN 36-72 HOURS WITH THE USE OF GYPSUM.
 12. DEWATERING SHALL BE DONE IN SUCH A MANNER AS TO REMOVE THE RELATIVELY CLEAN WATER WITHOUT REMOVING OR DISTURBING THE SEDIMENT THAT HAS SETTLED. THE PUMP INTAKE PIPE IS NOT TO REST ON THE SETTLED SEDIMENT LAYER.
 13. IF WATER EXCEEDS TSS OF 50mg/L (75 NTU) DURING DEWATERING, PUMPING IS TO CEASE.
 14. RECORDS ARE TO BE KEPT (ON-SITE AT ALL TIMES) OF ALL MEASUREMENT PRIOR TO, DURING AND AFTER DISCHARGE. RECORDS TO BE MADE AVAILABLE TO COUNCIL OFFICERS UPON REQUEST.



SEDIMENT STORAGE MARKER

SCALE 1:20

TYPICAL SEDIMENT CONTROL BASIN SECTION

SCALE 1:50

FOR DEVELOPMENT

APPROVAL

ARCHITECT	
ISSUED FOR REVIEW	16.12.15
ISSUED FOR REVIEW	15.12.15
AMENDMENTS	

CLIENT	LOGOS PROPERTY
	SUITE 02, LEVEL 12
	167 MACQUARIE STREET
	SYDNEY NSW

PROJECT	PROPOSED DEVELOPMENT
	LOT 62/133-145 LENORE LANE,
	ERSKINE PARK NSW
DESIGNED (P/NAME)	MW
SD	
DATE	
CHECKED	
SIZE	AT
SCALE	AS SHOWN
CAD REF:	11888-04-DA26

Costin Roe Consulting Pty Ltd.
Consulting Engineers
Level 1, 8 Miranda Street
Miranda NSW 2225
Tel: (02) 9290 7200 Fax: (02) 9290 7201
email: mail@costinroe.com.au ©

CostinRoe Consulting
Value in Engineering and Management

DRAWING TITLE	EROSION AND SEDIMENT CONTROL DETAILS-SHEET 2
DRAWING No	C011888-04-DA26
ISSUE	B