

All communications to be addressed to:

Headquarters
NSW Rural Fire Service
Locked Mail Bag 17
GRANVILLE NSW 2142

Headquarters
NSW Rural Fire Service
15 Carter Street
Lidcombe NSW 2141


Telephone: (02) 8741 5555

Facsimile: (02) 8741 5550

e-mail: development.assessment@rfs.nsw.gov.au



Department of Planning
Major Development Assessment
GPO Box 39
SYDNEY NSW 2001



PCU015243

Attention: Felicity Greenway

30 September 2010

Dear Ms Greenway

Teralba Waste Recycling Project - 08_0079
Exhibition of Environmental Assessment

I refer to your letter seeking comments on the Environmental Assessment from the NSW Rural Fire Service (RFS) regarding bush fire protection for the above proposal.


The RFS has reviewed the submitted plans and information and supports the bush fire protection measures contained within the bushfire protection assessment report prepared by Australian Bushfire Protection Planners, ref. BO91021 - 1, dated 21/06/2010, except where modified below.

- The construction of the proposed office building shall comply with section 7 (BAL 29) Australian Standard AS3959-2009 'Construction of buildings in bush fire-prone areas' and section A3.7 Addendum Appendix 3 of 'Planning for Bush Fire Protection'.

For any enquiries regarding this correspondence please contact Garth Bladwell.

Yours faithfully,

Corey Shackleton
A/Team Leader Development Assessment and Planning



For information on *Planning for Bush Fire Protection 2006* visit the RFS web page www.rfs.nsw.gov.au