



COMMUNITY SAFETY DIRECTORATE
STRUCTURAL FIRE SAFETY UNIT
Amarina Avenue Greenacre NSW 2190
Locked Bag 12 Greenacre NSW 2190

www.fire.nsw.gov.au

info@fire.nsw.gov.au

ABN 12 593 473 110

Your Reference:

File No: NFB/02568

Contact Officer: Alan Bruce

Telephone: (02) 9742 7400

Facsimile: (02) 9742 7483

Email: firesafety.nswfb@fire.nsw.gov.au

20 January 2012

NSW Department of Planning & Infrastructure
23-33 Bridge Street
SYDNEY NSW 2000

Email: information@planning.nsw.gov.au

CC: Nicholas.hall@planning.nsw.gov.au

Attention: Nicholas Hall

Dear Sir

**RE: ASSESSMENT OF MARSTEL BULK FUEL STORAGE AND DISPATCH FACILITY
(MP 08_0130) INDUSTRIAL DRIVE, MAYFIELD NORTH**

I refer to your correspondence dated 18 January 2012 requesting Fire and Rescue NSW (FRNSW) to review and comment on an Environmental Assessment (EA) for the proposed Marstel Bulk Fuel Storage and Dispatch Facility. The EA, (Version 60212465 revision C) dated 4 November 2011, was prepared by Jessica Miller and Simon Murphy of AECOM Australia Pty Ltd.

FRNSW has reviewed the submitted EA and the following comments are provided:

1. FRNSW believes that the site's operators should prepare and submit to FRNSW an Emergency Plan (EP). It is recommended that the EP follow FRNSW Policy No 1: *Guidelines for Emergency Plans at Facilities Having Notifiable Quantities of Dangerous Goods* and Hazardous Industry Planning Advisory Paper (HIPAP) N0.1
2. Referring to Sections 3.6.12 and 7.3 of the EA, FRNSW concurs that a Fire Safety Study (FSS) should be prepared, and further recommends it be prepared in accordance with HIPAP No. 2. If deemed appropriate by the Approval Authority, FRNSW can provide comment on the FSS.

Should you have any further enquiries regarding any of the above matters, please do not hesitate to contact the Structural Fire Safety Unit.

Yours faithfully

Electronically approved for release

For Commissioner