
NOTES:

- * (A)(B)(C)(D)(E)(F) Approximate Location of Overhang Features
- * To be read in conjuction with text of report and Figures 7 to 12
- * For explanation of mapping symbols see Figure 13




LEGEND BOREHOLE SCALE (m) TEST PIT


20

GEOTECHNICAL SITE PLAN

Jeffery and Katauskas Pty Ltd consulting geotechnical & environmental engineers

Report No. 22706VT Figure No. 1






SANDSTONE fine to medium grained, light brown. DW, L

END OF TEST PIT AT 0.57m GROUNDWATER NOT ENCOUNTERED

TEST PIT 5 CROSS SECTIONAL SKETCH LOOKING NORTH






END OF TEST PIT AT 0.65m GROUND WATER NOT ENCOUNTERED

TEST PIT 6 **CROSS SECTIONAL SKETCH** LOOKING NORTH



Jeffery and Katauskas Pty Ltd consulting geotechnical & environmental engineers

Figure No 4



END OF TEST PIT AT 0.65m. GROUNDWATER NOT ENCOUNTERED

TEST PIT 7 CROSS SECTIONAL SKETCH LOOKING NORTH



Jeffery and Katauskas Pty Ltd consulting geotechnical & environmental engineers











Looking north – Chainage ≈22m






Chainage ≈42m

View of Western Rock Face Approximate Chainage 9.5m to 42m









Looking west – Chainage ≈45m



Chainage ≈77m

View of Western Rock Face Approximate Chainage 40m to 77m

To be read in conjunction with text of report.









Looking south – Chainage ≈93m



Looking north – Chainage ≈78m



Chainage ≈107m

View of Western Rock Face Approximate Chainage 75m to 107m





Looking south – Chainage ≈137m



Chainage ≈138m

View of South-Western Rock Face Approximate Chainage 115m to 138m






Looking west – Chainage ≈155m




Chainage ≈160m


View of Southern Rock Face Approximate Chainage 135m to 160m




OVERHANG: A (CH 22m) CROSS SECTIONAL SKETCH LOOKING NORTH









OVERHANG: B (CH 41m) CROSS SECTIONAL SKETCH LOOKING NORTH








OVERHANG: C (CH 78m) CROSS SECTIONAL SKETCH **LOOKING NORTH**



OVERHANG: D (CH 93m) CROSS SECTIONAL SKETCH LOOKING SOUTH








OVERHANG: E (CH 103m) CROSS SECTIONAL SKETCH LOOKING NORTH








OVERHANG: F (CH 155m) CROSS SECTIONAL SKETCH LOOKING WEST






Report No. 22706VT

Figure No 12



EXAMPLE OF USE OF TOPOGRAPHIC SYMBOLS:




GEOTECHNICAL MAPPING SYMBOLS

Jeffery and Katauskas Pty Ltd CONSULTING GEOTECHNICAL & ENVIRONMENTAL ENGINEERS



Report No. 22706VT

Figure No. 13



Jeffery and Katauskas Pty Ltd

CONSULTING GEOTECHNICAL AND ENVIRONMENTAL ENGINEERS A.C.N. 003 550 801



VIBRATION EMISSION DESIGN GOALS

German Standard DIN 4150 – Part 3: 1986 provides guideline levels of vibration velocity for evaluating the effects of vibration in structures. The limits presented in this standard are generally recognised to be conservative.

The DIN 4150 values (maximum levels measured in any direction at the foundation, OR, maximum levels measured in (x) or (y) horizontal directions, in the plane of the uppermost floor), are summarised in Table 1 below.

It should be noted that peak vibration velocities higher than the minimum figures in Table 1 for low frequencies may be quite "safe", depending on the frequency content of the vibration and the actual condition of the structure.

It should also be noted that these levels are "safe limits", up to which no damage due to vibration effects has been observed for the particular class of building. "Damage" is defined by DIN 4150 to include even minor non-structural effects such as superficial cracking in cement render, the enlargement of cracks already present, and the separation of partitions or intermediate walls from load bearing walls. Should damage be observed at vibration levels lower than the "safe limits" then it may be attributed to other causes. DIN 4150 also states that when vibration levels higher than the "safe limits" are present, it does not necessarily follow that damage will occur. Values given are only a broad guide.

Table 1 DIN 4150 - Structural Damage - Safe Limits for Building Vibration

		Peak Vibration Velocity in mm/s					
Group	Type of	At A	Plane of Floor of Uppermost				
	Structure		of		Storey		
		Less than 10 Hz	10 Hz to 50 Hz	50 Hz to 100 Hz	All Frequencies		
1	Buildings used for commercial purposes, industrial buildings and buildings of similar design.	20	20 to 40	40 to 50	40		
2	Dwellings and buildings of similar design and/or use.	5	5 to 15	15 to 20	15		
3	Structures that because of their particular sensitivity to vibration, do not correspond to those listed in Group 1 and 2 and have intrinsic value (eg buildings that are under a preservation order).	3	3 to 8	8 to 10	8		

Note: For frequencies above 100 Hz, the higher values in the 50 Hz to 100 Hz column should be used.

Jeffery and Katauskas Pty Ltd

CONSULTING GEOTECHNICAL AND ENVIRONMENTAL ENGINEERS ABN 17 003 550 801



REPORT EXPLANATION NOTES

INTRODUCTION

These notes have been provided to amplify the geotechnical report in regard to classification methods, field procedures and certain matters relating to the Comments and Recommendations section. Not all notes are necessarily relevant to all reports.

The ground is a product of continuing natural and manmade processes and therefore exhibits a variety of characteristics and properties which vary from place to place and can change with time. Geotechnical engineering involves gathering and assimilating limited facts about these characteristics and properties in order to understand or predict the behaviour of the ground on a particular site under certain conditions. This report may contain such facts obtained by inspection, excavation, probing, sampling, testing or other means of investigation. If so, they are directly relevant only to the ground at the place where and time when the investigation was carried out.

DESCRIPTION AND CLASSIFICATION METHODS

The methods of description and classification of soils and rocks used in this report are based on Australian Standard 1726, the SAA Site Investigation Code. In general, descriptions cover the following properties – soil or rock type, colour, structure, strength or density, and inclusions. Identification and classification of soil and rock involves judgement and the Company infers accuracy only to the extent that is common in current geotechnical practice.

Soil types are described according to the predominating particle size and behaviour as set out in the attached Unified Soil Classification Table qualified by the grading of other particles present (eg sandy clay) as set out below:

Soil Classification	Particle Size
Clay	less than 0.002mm
Silt	0.002 to 0.06mm
Sand	0.06 to 2mm
Gravel	2 to 60mm

Non-cohesive soils are classified on the basis of relative density, generally from the results of Standard Penetration Test (SPT) as below:

Relative Density	SPT 'N' Value (blows/300mm)
Very loose	less than 4
Loose	4 – 10
Medium dense	10 – 30
Dense	30 - 50
Very Dense	greater than 50

Cohesive soils are classified on the basis of strength (consistency) either by use of hand penetrometer, laboratory testing or engineering examination. The strength terms are defined as follows.

Classification	Unconfined Compressive Strength kPa
Very Soft	less than 25
Soft	25 – 50
Firm	50 – 100
Stiff	100 – 200
Very Stiff	200 - 400
Hard	Greater than 400
Friable	Strength not attainable - soil crumbles

Rock types are classified by their geological names, together with descriptive terms regarding weathering, strength, defects, etc. Where relevant, further information regarding rock classification is given in the text of the report. In the Sydney Basin, 'Shale' is used to describe thinly bedded to laminated siltstone.

SAMPLING

Sampling is carried out during drilling or from other excavations to allow engineering examination (and laboratory testing where required) of the soil or rock.

Disturbed samples taken during drilling provide information on plasticity, grain size, colour, moisture content, minor constituents and, depending upon the degree of disturbance, some information on strength and structure. Bulk samples are similar but of greater volume required for some test procedures.

Undisturbed samples are taken by pushing a thin-walled sample tube, usually 50mm diameter (known as a U50), into the soil and withdrawing it with a sample of the soil contained in a relatively undisturbed state. Such samples yield information on structure and strength, and are necessary for laboratory determination of shear strength and compressibility. Undisturbed sampling is generally effective only in cohesive soils.

Details of the type and method of sampling used are given on the attached logs.

INVESTIGATION METHODS

The following is a brief summary of investigation methods currently adopted by the Company and some comments on their use and application. All except test pits, hand auger drilling and portable dynamic cone penetrometers require the use of a mechanical drilling rig which is commonly mounted on a truck chassis.



Test Pits: These are normally excavated with a backhoe or a tracked excavator, allowing close examination of the insitu soils if it is safe to descend into the pit. The depth of penetration is limited to about 3m for a backhoe and up to 6m for an excavator. Limitations of test pits are the problems associated with disturbance and difficulty of reinstatement and the consequent effects on close-by structures. Care must be taken if construction is to be carried out near test pit locations to either properly recompact the backfill during construction or to design and construct the structure so as not to be adversely affected by poorly compacted backfill at the test pit location.

Hand Auger Drilling: A borehole of 50mm to 100mm diameter is advanced by manually operated equipment. Premature refusal of the hand augers can occur on a variety of materials such as hard clay, gravel or ironstone, and does not necessarily indicate rock level.

Continuous Spiral Flight Augers: The borehole is advanced using 75mm to 115mm diameter continuous spiral flight augers, which are withdrawn at intervals to allow sampling and insitu testing. This is a relatively economical means of drilling in clays and in sands above the water table. Samples are returned to the surface by the flights or may be collected after withdrawal of the auger flights, but they can be very disturbed and layers may become mixed. Information from the auger sampling (as distinct from specific sampling by SPTs or undisturbed samples) is of relatively lower reliability due to mixing or softening of samples by groundwater, or uncertainties as to the original depth of the samples. Augering below the groundwater table is of even lesser reliability than augering above the water table.

Rock Augering: Use can be made of a Tungsten Carbide (TC) bit for auger drilling into rock to indicate rock quality and continuity by variation in drilling resistance and from examination of recovered rock fragments. This method of investigation is quick and relatively inexpensive but provides only an indication of the likely rock strength and predicted values may be in error by a strength order. Where rock strengths may have a significant impact on construction feasibility or costs, then further investigation by means of cored boreholes may be warranted.

Wash Boring: The borehole is usually advanced by a rotary bit, with water being pumped down the drill rods and returned up the annulus, carrying the drill cuttings. Only major changes in stratification can be determined from the cuttings, together with some information from "feel" and rate of penetration.

Mud Stabilised Drilling: Either Wash Boring or Continuous Core Drilling can use drilling mud as a circulating fluid to stabilise the borehole. The term 'mud' encompasses a range of products ranging from bentonite to polymers such as Revert or Biogel. The mud tends to mask the cuttings and reliable identification is only possible from intermittent intact sampling (eg from SPT and U50 samples) or from rock coring, etc.

Continuous Core Drilling: A continuous core sample is obtained using a diamond tipped core barrel. Provided full core recovery is achieved (which is not always possible in very low strength rocks and granular soils), this technique provides a very reliable (but relatively expensive) method of investigation. In rocks, an NMLC triple tube core barrel, which gives a core of about 50mm diameter, is usually used with water flush. The length of core recovered is compared to the length drilled and any length not recovered is shown as CORE LOSS. The location of losses are determined on site by the supervising engineer; where the location is uncertain, the loss is placed at the top end of the drill run.

Standard Penetration Tests: Standard Penetration Tests (SPT) are used mainly in non-cohesive soils, but can also be used in cohesive soils as a means of indicating density or strength and also of obtaining a relatively undisturbed sample. The test procedure is described in Australian Standard 1289, "Methods of Testing Soils for Engineering Purposes" – Test F3.1.

The test is carried out in a borehole by driving a 50mm diameter split sample tube with a tapered shoe, under the impact of a 63kg hammer with a free fall of 760mm. It is normal for the tube to be driven in three successive 150mm increments and the 'N' value is taken as the number of blows for the last 300mm. In dense sands, very hard clays or weak rock, the full 450mm penetration may not be practicable and the test is discontinued.

The test results are reported in the following form:

 In the case where full penetration is obtained with successive blow counts for each 150mm of, say, 4, 6 and 7 blows, as

$$N = 13$$
 4, 6, 7

 In a case where the test is discontinued short of full penetration, say after 15 blows for the first 150mm and 30 blows for the next 40mm, as

The results of the test can be related empirically to the engineering properties of the soil.

Occasionally, the drop hammer is used to drive 50mm diameter thin walled sample tubes (U50) in clays. In such circumstances, the test results are shown on the borehole logs in brackets.

A modification to the SPT test is where the same driving system is used with a solid 60° tipped steel cone of the same diameter as the SPT hollow sampler. The solid cone can be continuously driven for some distance in soft clays or loose sands, or may be used where damage would otherwise occur to the SPT. The results of this Solid Cone Penetration Test (SCPT) are shown as "No" on the borehole logs, together with the number of blows per 150mm penetration.



Static Cone Penetrometer Testing and Interpretation: Cone penetrometer testing (sometimes referred to as a Dutch Cone) described in this report has been carried out using an Electronic Friction Cone Penetrometer (EFCP). The test is described in Australian Standard 1289, Test F5.1.

In the tests, a 35mm diameter rod with a conical tip is pushed continuously into the soil, the reaction being provided by a specially designed truck or rig which is fitted with an hydraulic ram system. Measurements are made of the end bearing resistance on the cone and the frictional resistance on a separate 134mm long sleeve, immediately behind the cone. Transducers in the tip of the assembly are electrically connected by wires passing through the centre of the push rods to an amplifier and recorder unit mounted on the control truck.

As penetration occurs (at a rate of approximately 20mm per second) the information is output as incremental digital records every 10mm. The results given in this report have been plotted from the digital data.

The information provided on the charts comprise:

- Cone resistance the actual end bearing force divided by the cross sectional area of the cone – expressed in MPa.
- Sleeve friction the frictional force on the sleeve divided by the surface area – expressed in kPa.
- Friction ratio the ratio of sleeve friction to cone resistance, expressed as a percentage.

The ratios of the sleeve resistance to cone resistance will vary with the type of soil encountered, with higher relative friction in clays than in sands. Friction ratios of 1% to 2% are commonly encountered in sands and occasionally very soft clays, rising to 4% to 10% in stiff clays and peats. Soil descriptions based on cone resistance and friction ratios are only inferred and must not be considered as exact.

Correlations between EFCP and SPT values can be developed for both sands and clays but may be site specific.

Interpretation of EFCP values can be made to empirically derive modulus or compressibility values to allow calculation of foundation settlements.

Stratification can be inferred from the cone and friction traces and from experience and information from nearby boreholes etc. Where shown, this information is presented for general guidance, but must be regarded as interpretive. The test method provides a continuous profile of engineering properties but, where precise information on soil classification is required, direct drilling and sampling may be preferable.

Portable Dynamic Cone Penetrometers: Portable Dynamic Cone Penetrometer (DCP) tests are carried out by driving a rod into the ground with a sliding hammer and counting the blows for successive 100mm increments of penetration.

Two relatively similar tests are used:

- Cone penetrometer (commonly known as the Scala Penetrometer) – a 16mm rod with a 20mm diameter cone end is driven with a 9kg hammer dropping 510mm (AS1289, Test F3.2). The test was developed initially for pavement subgrade investigations, and correlations of the test results with California Bearing Ratio have been published by various Road Authorities.
- Perth sand penetrometer a 16mm diameter flat ended rod is driven with a 9kg hammer, dropping 600mm (AS1289, Test F3.3). This test was developed for testing the density of sands (originating in Perth) and is mainly used in granular soils and filling.

LOGS

The borehole or test pit logs presented herein are an engineering and/or geological interpretation of the subsurface conditions, and their reliability will depend to some extent on the frequency of sampling and the method of drilling or excavation. Ideally, continuous undisturbed sampling or core drilling will enable the most reliable assessment, but is not always practicable or possible to justify on economic grounds. In any case, the boreholes or test pits represent only a very small sample of the total subsurface conditions.

The attached explanatory notes define the terms and symbols used in preparation of the logs.

Interpretation of the information shown on the logs, and its application to design and construction, should therefore take into account the spacing of boreholes or test pits, the method of drilling or excavation, the frequency of sampling and testing and the possibility of other than "straight line" variations between the boreholes or test pits. Subsurface conditions between boreholes or test pits may vary significantly from conditions encountered at the borehole or test pit locations.

GROUNDWATER

Where groundwater levels are measured in boreholes, there are several potential problems:

- Although groundwater may be present, in low permeability soils it may enter the hole slowly or perhaps not at all during the time it is left open.
- A localised perched water table may lead to an erroneous indication of the true water table.
- Water table levels will vary from time to time with seasons or recent weather changes and may not be the same at the time of construction.
- The use of water or mud as a drilling fluid will mask any groundwater inflow. Water has to be blown out of the hole and drilling mud must be washed out of the hole or 'reverted' chemically if water observations are to be made.



More reliable measurements can be made by installing standpipes which are read after stabilising at intervals ranging from several days to perhaps weeks for low permeability soils. Piezometers, sealed in a particular stratum, may be advisable in low permeability soils or where there may be interference from perched water tables or surface water.

FILL

The presence of fill materials can often be determined only by the inclusion of foreign objects (eg bricks, steel etc) or by distinctly unusual colour, texture or fabric. Identification of the extent of fill materials will also depend on investigation methods and frequency. Where natural soils similar to those at the site are used for fill, it may be difficult with limited testing and sampling to reliably determine the extent of the fill.

The presence of fill materials is usually regarded with caution as the possible variation in density, strength and material type is much greater than with natural soil deposits. Consequently, there is an increased risk of adverse engineering characteristics or behaviour. If the volume and quality of fill is of importance to a project, then frequent test pit excavations are preferable to boreholes.

LABORATORY TESTING

Laboratory testing is normally carried out in accordance with Australian Standard 1289 'Methods of Testing Soil for Engineering Purposes'. Details of the test procedure used are given on the individual report forms.

ENGINEERING REPORTS

Engineering reports are prepared by qualified personnel and are based on the information obtained and on current engineering standards of interpretation and analysis. Where the report has been prepared for a specific design proposal (eg. a three storey building) the information and interpretation may not be relevant if the design proposal is changed (eg to a twenty storey building). If this happens, the company will be pleased to review the report and the sufficiency of the investigation work.

Every care is taken with the report as it relates to interpretation of subsurface conditions, discussion of geotechnical aspects and recommendations or suggestions for design and construction. However, the Company cannot always anticipate or assume responsibility for:

- Unexpected variations in ground conditions the potential for this will be partially dependent on borehole spacing and sampling frequency as well as investigation technique.
- Changes in policy or interpretation of policy by statutory authorities.
- The actions of persons or contractors responding to commercial pressures.

If these occur, the company will be pleased to assist with investigation or advice to resolve any problems occurring.

SITE ANOMALIES

In the event that conditions encountered on site during construction appear to vary from those which were expected from the information contained in the report, the company requests that it immediately be notified. Most problems are much more readily resolved when conditions are exposed that at some later stage, well after the event.

REPRODUCTION OF INFORMATION FOR CONTRACTUAL **PURPOSES**

Attention is drawn to the document 'Guidelines for the Provision of Geotechnical Information in Tender Documents', published by the Institution of Engineers, Australia. Where information obtained from this investigation is provided for tendering purposes, it is recommended that all information, including the written report and discussion, be made available. In circumstances where the discussion or comments section is not relevant to the contractual situation, it may be appropriate to prepare a specially edited document. The company would be pleased to assist in this regard and/or to make additional report copies available for contract purposes at a nominal charge.

Copyright in all documents (such as drawings, borehole or test pit logs, reports and specifications) provided by the Company shall remain the property of Jeffery and Katauskas Pty Ltd. Subject to the payment of all fees due, the Client alone shall have a licence to use the documents provided for the sole purpose of completing the project to which they relate. License to use the documents may be revoked without notice if the Client is in breach of any objection to make a payment to us.

REVIEW OF DESIGN

Where major civil or structural developments are proposed or where only a limited investigation has been completed or where the geotechnical conditions/ constraints are quite complex, it is prudent to have a joint design review which involves a senior geotechnical engineer.

SITE INSPECTION

The company will always be pleased to provide engineering inspection services for geotechnical aspects of work to which this report is related.

Requirements could range from:

- a site visit to confirm that conditions exposed are no worse than those interpreted, to
- ii) a visit to assist the contractor or other site personnel in identifying various soil/rock types such as appropriate footing or pier founding depths, or
- iii) full time engineering presence on site.



GRAPHIC LOG SYMBOLS FOR SOILS AND ROCKS

SOIL ROCK **DEFECTS AND INCLUSIONS** FILL CONGLOMERATE CLAY SEAM TOPSOIL SANDSTONE SHEARED OR CRUSHED CLAY (CL, CH) SHALE **BRECCIATED OR** SHATTERED SEAM/ZONE 000 SILTSTONE, MUDSTONE, SILT (ML, MH) **IRONSTONE GRAVEL** 9 9 CLAYSTONE SAND (SP, SW) LIMESTONE ORGANIC MATERIAL GRAVEL (GP, GW) PHYLLITE, SCHIST **OTHER MATERIALS** SANDY CLAY (CL, CH) TUFF CONCRETE SILTY CLAY (CL, CH) GRANITE, GABBRO BITUMINOUS CONCRETE, COAL CLAYEY SAND (SC) DOLERITE, DIORITE COLLUVIUM SILTY SAND (SM) BASALT, ANDESITE GRAVELLY CLAY (CL, CH) QUARTZITE CLAYEY GRAVEL (GC) SANDY SILT (ML) PEAT AND ORGANIC SOILS

Jeffery and Katauskas Pty Ltd consulting geotechnical & environmental engineers



UNIFIED SOIL CLASSIFICATION TABLE

	Field Identification Procedures (Excluding particles larger than 75 µm and basing fractions on estimated weights)				Group Symbols	Typical Names	Information Required for Describing Soils		Laboratory Classification Criteria		
s rial is sizeb ve)	Gravels More than half of coarse fraction is larger than 4 mm steve size	Clean gravels (little or no fines)			and substantial ediate particle	G₩	Well graded gravels, gravel sand mixtures, little or no fines	Give typical name; indicate ap- proximate percentages of sand	than 75 follows:	$C_{0} = \frac{D_{60}}{D_{10}}$ Greater than 4 $C_{0} = \frac{(D_{30})^{2}}{D_{10} \times D_{60}}$ Between 1 and 3	
	avels half of larger steve st	Clear	Predominant with some	ly one size or :	a range of sizes sizes missing	GP	Poorly graded gravels, gravel- sand mixtures, little or no fines		from g maller fied as	Not meeting all gradation requirements for G#	
	Grethan ction is	Gravels with fines (appreciable amount of fines)	Nonplastic fines (for identification pro- cedures see ML below)		GM	Silty gravels, poorly graded gravel-sand-silt mixtures	and other pertinent descriptive information; and symbols in parentheses	action streetassis, SC	Atterberg limits below Above "A" lime "A" line, or PI less with PI between than 4 and 7 are		
ined soi of mate	M _o		Plastic fines (for identificati ow)	on procedures,	GC	Clayey gravels, poorly graded gravel-sand-clay mixtures	tion on stratification, degree of compactness, cementation,	field identification iss of gravel and a tage of fines (frac GW, GP, SW, flac, GW, GP, SW, flacing of fines	Atterberg limits above requiring use of dual symbols	
Coarse-grained soils More than half of material is larger than 15 µm sleve sizeb smullest particle visible to nuked eye)	Sands More than half of ocarse fraction is smaller than 4 mm steve size	sleve size Clean sands (little or no			nd substantial diate particle	SW	Well graded sands, gravelly sands, little or no fines	moisture conditions and drainage characteristics Example: Silty sand, gravelly: about 20%	ctions as given under field identification Determine percentages of gravel and sand from grain size curve Depending on percentage of fines (fraction smaller than 75 µm sive size) coarse grained soils are classified as follows: Less than 5% GW GP, SW SP MOVE that 12% GM, GC, SW, SC SM,	$C_{0} = \frac{D_{60}}{D_{10}} \text{Greater than 6}$ $C_{C} = \frac{(D_{30})^{2}}{D_{10} \times D_{60}} \text{Between 1 and 3}$	
			Predominant with some	ly one size or a intermediate	range of sizes sizes missing	SP	Poorly graded sands, gravelly sands, little or no fines	hard, angular gravel par- ticles 12 mm maximum size: rounded and subangularsand grains coarse to fine, about	given under ne percentage on percentage than 5% than 12% to 12% t	Not meeting all gradation requirements for SW	
		Sands with fines (appreciable amount of fines)	Nonplastic fi	nes (for ident	tification pro-)	SM	Silty sands, poorly graded sand- silt mixtures	15% non-plastic fines with low dry strength; well com- pacted and moist in place:	ernine urve urve conding m sieve Less th More (Atterberg limits below Above "A" line "A" line or PI less than with PI between 4 and 7 are	
ut the s	Σ"-			Plastic fines (for identification procedures, see CL below) n Fraction Smaller than 380 µm Sieve Size		SC	Clayey sands, poorly graded sand-clay mixtures	alluvial sand; (SM)	E l	Atterberg limits below requiring use of dual symbols	
abo	Identification	Procedures o	Dry Strength	aller than 380	µm Sieve Size				₽ ₽		
More than half of material is smaller than 181 of material is smaller than 75 µm sleve size (The 75 µm sleve size is a	\$ _	S.		Dilatancy (reaction to shaking)	Toughness (consistency near plastic limit)				80 Gomp	aring soils at equal liquid limit	
	Silts and clays liquid limit less than 50		None to slight	Quick to slow	None	ML	Inorganic silts and very fine sands, rock flour, silty or clayey fine sands with slight plasticity	Give typical name; indicate degree and character of plasticity, 9 9 40 Toug	index index	40 Toughness and dry strength increase with increasing obsticity index	
			Medium to high	None to very slow	Medium	CL	Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, siity clays, lean clays		011		
			Slight to medium	Slow	Slight	OL	Organic silts and organic silt- clays of low plasticity	For undisturbed soils add infor-	ğ 10	a a m	
	Siits and clays Iquid linit Brente than 50		Slight to medium High to	Slow to none	Slight to medium	МН	Inorganic silts, micaceous or diatomaceous fine sandy or silty soils, elastic silts	mation on structure, stratifica- tion, consistency in undisturbed and remoulded states, moisture and drainage conditions	0 10	20 30 40 50 60 70 80 90 100	
Σ	is any quid cater	is an ignition of the state of		None	High	CH	Inorganic clays of high plas- ticity, fat clays	Example:		Liquid limit	
	S # S		Medium to high	None to very slow	Slight to medium	ОН	Organic clays of medium to high plasticity	Clayey silt, brown; slightly plastic; small percentage of	for labor	Plasticity chart	
	Readily identified by colour, odour,		Pt	Peat and other highly organic soils	fine sand; numerous vertical root holes; firm and dry in place; loss; (ML)	10: 1800	ratory classification of fine grained soils				

NOTE: 1) Soils possessing characteristics of two groups are designated by combinations of group symbols (e.g. GW-GC, well graded gravel-sand mixture with clay fines).

2) Soils with liquid limits of the order of 35 to 50 may be visually classified as being of medium plasticity.

Jeffery and Katauskas Pty Ltd consulting geotechnical and environmental engineers

ABN 17 003 550 801



LOG SYMBOLS

rog corumn	SYMBOL	DEFINITION				
Groundwater Record	E	Standing water level. Time delay following completion of drilling may be shown.				
	-c-	Extent of borehole collapse shortly after drilling.				
		Groundwater seepage into borehole or excavation noted during drilling or excavation.				
Samples	ES	Soil sample taken over depth indicated, for environmental analysis.				
	U50	Undisturbed 50mm diameter tube sample taken over depth indicated. Bulk disturbed sample taken over depth indicated.				
	DB					
	DS	Small disturbed bag sample taken over depth indicated.				
	ASB	Soil sample taken over depth indicated, for asbestos screening.				
	ASS	Soil sample taken over depth indicated, for acid sulfate soil analysis.				
	SAL	Soil sample taken over depth indicated, for salinity analysis.				
Field Tests	N = 17 4, 7, 10	Standard Penetration Test (SPT) performed between depths indicated by lines. Individual figures show blows per 150mm penetration. 'R' as noted below.				
	No = 5 7 3R	Solid Cone Penetration Test (SCPT) performed between depths indicated by lines. Individual figures show blows per 150mm penetration for 60 degree solid cone driven by SPT hammer. 'R' refers to apparent hammer refusal within the corresponding 150mm depth increment.				
	VNS = 25	Vane shear reading in kPa of Undrained Shear Strength.				
	PID = 100	Photoionisation detector reading in ppm (Soil sample headspace test).				
Moisture Condition	MC>PL	Moisture content estimated to be greater than plastic limit.				
(Cohesive Soils)	MC≈PL	Moisture content estimated to be approximately equal to plastic limit.				
	MC < PL	Moisture content estimated to be less than plastic limit.				
(Cohesionless Soils)	D	DRY - runs freely through fingers,				
(Conesioniess 30115)	М	MOIST - does not run freely but no free water visible on soil surface.				
	w	WET - free water visible on soil surface.				
Strength (Consistency)	VS	VERY SOFT - Unconfined compressive strength less than 25kPa				
Cohesive Soils	s	SOFT - Unconfined compressive strength 25-50kPa				
	F	FIRM - Unconfined compressive strength 50-100kPa				
	St	STIFF - Unconfined compressive strength 100-200kPa				
	VSt	VERY STIFF - Unconfined compressive strength 200-400kPa				
	Н	HARD - Unconfined compressive strength greater than 400kPa				
	()	Bracketed symbol indicates estimated consistency based on tactile examination or other tests.				
Density Index/ Relative	· · · · · · · · · · · · · · · · · · ·	Density Index (lo) Range (%) SPT 'N' Value Range (Blows/300mm)				
Density (Cohesionless	VL	Very Loose <15 0-4				
Soils)	L	Loose 15-35 4-10				
	MD	Medium Dense 35-65 10-30				
	D	Dense 65-85 30-50				
	VD	Very Dense >85 >50				
	()	Bracketed symbol indicates estimated density based on ease of drilling or other tests.				
Hand Penetrometer	300	Numbers indicate individual test results in kPa on representative undisturbed material unless noted				
Readings	250	otherwise,				
Domorko	'V' bit	Hardened steel 'V' shaped bit.				
Remarks						
	'TC' bit	Tungsten carbide wing bit.				
	60	Penetration of auger string in mm under static load of rig applied by drill head hydraulics without rotation of augers.				

Ref: Standard Sheets/Log Symbols

November 2007

Jeffery and Katauskas Pty Ltd

CONSULTING GEOTECHNICAL AND ENVIRONMENTAL ENGINEERS
ABN 17 003 550 801



LOG SYMBOLS

ROCK MATERIAL WEATHERING CLASSIFICATION

TERM	SYMBOL	DEFINITION
Residual Soil	RS	Soil developed on extremely weathered rock; the mass structure and substance fabric are no longer evident; there is a large change in volume but the soil has not been significantly transported.
Extremely weathered rock	xw	Rock is weathered to such an extent that it has "soil" properties, ie it either disintegrates or can be remoulded, in water.
Distinctly weathered rock	DW	Rock strength usually changed by weathering. The rock may be highly discoloured, usually by ironstaining. Porosity may be increased by leaching, or may be decreased due to deposition of weathering products in pores.
Slightly weathered rock	sw	Rock is slightly discoloured but shows little or no change of strength from fresh rock.
Fresh rock	FR	Rock shows no sign of decomposition or staining.

ROCK STRENGTH

Rock strength is defined by the Point Load Strength Index (Is 50) and refers to the strength of the rock substance in the direction normal to the bedding. The test procedure is described by the International Journal of Rock Mechanics, Mining, Science and Geomechanics. Abstract Volume 22, No 2, 1985.

TERM	SYMBOL	ls (50) MPa	FIELD GUIDE
Extremely Low:	EL	0.00	Easily remoulded by hand to a material with soil properties.
Very Low:	VL	0.03	May be crumbled in the hand. Sandstone is "sugary" and friable.
Low:	L	0.1	A piece of core 150mm long x 50mm dia, may be broken by hand and easily scored with a knife. Sharp edges of core may be friable and break during handling.
Medium Strength:	M	0.3	A piece of core 150mm long x 50mm dia, can be broken by hand with difficulty.
		1	Readily scored with knife.
High:	Н	3	A piece of core 150mm long x 50mm dia. core cannot be broken by hand, can be slightly scratched or scored with knife; rock rings under hammer.
Very High:	VH		A piece of core 150mm long x 50mm dla, may be broken with hand-held pick after
		10	more than one blow. Cannot be scratched with pen knife; rock rings under hammer.
Extremely High:	EH	:	A piece of core 150mm long x 50mm dla. is very difficult to break with hand-held hammer. Rings when struck with a hammer.

ABBREVIATIONS USED IN DEFECT DESCRIPTION

ABBREVIATION	DESCRIPTION	NOTES
Be .	Bedding Plane Parting	Defect orientations measured relative to the normal to the long core axis
CS	Clay Seam	(ie relative to horizontal for vertical holes)
J	Joint	
Р	Planar	
Un	Undulating	
S	Smooth	
R	Rough	
18	Ironstained	
xws	Extremely Weathered Seam	
Cr	Crushed Seam	
60t	Thickness of defect in millimetres	

Ref: Standard Sheets/Log Symbols

November 2007