



ENVIRONMENT PROTECTION AUTHORITY

Your reference: MP08_0222 MOD 2
Our reference: DOC122632
Our contact: Dana Alderson 9995 6851

Ms Pilar Aberasturi
Metropolitan and Regional Projects South
NSW Department of Planning and Infrastructure
GPO Box 39
SYDNEY NSW 2001

Dear Ms Aberasturi,

Re: Section 75W Modification Application (MP08_0222 MOD 2) – Global Switch Sydney 2 Data Centre

I refer to the letter regarding the proposed modification to the approved Global Switch Sydney 2 Data Centre (the proposal) received by the Environment Protection Authority (EPA) on 23 January 2012.

The EPA has reviewed the proposal and additional information provided by the applicant regarding the proposal. It is the EPA's understanding that the proposal no longer involves a trigeneration system and that it has been replaced by conventional grid supply electricity, and that electric chillers and free cooling will be used for mechanical cooling. As such, an Environment Protection Licence (EPL) under the provisions of the *Protection of the Environment Operations Act 1997* (POEO Act) will not be required and the EPA has no further interest in this matter.

Please contact Dana Alderson on 9995 6851 if you have any queries regarding this letter.

Yours sincerely

 14/2/12

GREG SHEEHY
Manager, Sydney Industry
Environment Protection Authority