



570 George Street  
Sydney NSW 2000  
All mail to GPO Box 4009  
Sydney NSW 2001  
T +61 2 131 525  
F +61 2 9269 2830  
[www.ausgrid.com.au](http://www.ausgrid.com.au)

27 January 2012

Ms Pilar Aberasturi  
Department of Planning & Infrastructure  
23-33 Bridge Street  
Sydney, NSW, 2000

**Re: Section 75W Modification Application (MP08\_0222 MOD 2) – Global Switch Sydney 2 Data Centre, 273 Pyrmont Street, Ultimo**

Dear Pilar Aberasturi

I have perused the architectural drawings on the NSW Planning & Infrastructure website in regards to this proposed development ([http://majorprojects.planning.nsw.gov.au/index.pl?action=view\\_job&job\\_id=5128](http://majorprojects.planning.nsw.gov.au/index.pl?action=view_job&job_id=5128)) and it appears as though the basement and ground level of the proposed development extend to the site boundary on the Pyrmont Street side.

Following my investigation I would like to inform the relevant parties of the following:

- Ausgrid owns electrical infrastructure located within the premises being developed that will be affected by this proposal. Among these assets are in service high voltage and pilot cables.
- There are additional high voltage and pilot cables located in the footpath and the roadway surrounding the site that may be affected by the proposed building and/or construction activity.
- From the architectural drawings it appears that the 33kV customer substation S.7988 HARRIS QUARY (which is located in EXISTING GLOBAL SWITCH 1) will not be affected.

Further discussions will be required to determine how many affected assets will need to be relocated. Information on the relocation of assets process can be found on Ausgrid's website where there is a list of applicable documents and guidelines.  
<http://www.ausgrid.com.au/Common/Our-network/Standards-and-Guidelines/Electrical-supply-standards.aspx>

If you have any questions please contact me using one of the methods below.

Regards,

A handwritten signature in black ink, appearing to read "Jeffrey Crough", written over a horizontal line.

Jeffrey Crough

Engineer – Planning and Supply Negotiations

☎ +61 (0)2 9663 9221 | 📠 +61 (0)2 9663 9499 | ✉ [jcrough@ausgrid.com.au](mailto:jcrough@ausgrid.com.au)