



dem

Schedule of Additional Minor modifications (refer to numbered revision clouds on the drawings)

Drawing number	Revision cloud number	Floor level	Description of amendment
ar--1203	1	Ground	Stage 1 BMS/Security room relocated and area added to Meet Me Room
	2	Ground	Pit room within the Stage 1 Meet Me Room deleted as not required.
	3	Ground	Fire Room not longer needs to be increased in size in Stage 2
	4	Ground	Stage 1 BMS/Security room relocated to the end of Lift lobby
	5	Ground	Proposed Stage 3 Meet Me Room relocated to Stage 2 area between grids 16 and 17 (already covered in the submission).
ar--1204	6	First	Stage 1 BMS/Security room relocated from Lift lobby
	7	First	Stage 1 BMS/Security cupboard in lift lobby relocated (refer to item 6)
	8	First	Extended area of cloud indicating relocation of switch rooms & technical area already described in the current planning modification submission & already included in revised area calculations
ar--1205	9	Second	Stage 1 BMS room relocated
	10	Second	Riser duct deleted as no longer required.
	11	Second	Relocated position for Stage 1 BMS room.
	12	Second	Stage 1 BMS cupboard in lift lobby deleted.
	13	Second	Extended area of cloud indicating relocation of switch rooms & technical area already described in the current planning modification submission & already included in revised area calculations
ar--1206	14	Third	Riser duct deleted as no longer required.
	15	Third	Services cupboards deleted as no longer required.
	16	Third	Extended area of cloud indicating relocation of switch rooms & technical area already described in the current planning modification submission & already included in area revised calculations.
ar--1207	17	Fourth	Riser duct and air-conditioning plant room deleted as no longer required.
ar--1208	18	Fifth	Riser duct deleted as no longer required.
	19	Fifth	Change in size of UPS switch rooms in Stage 3 area
	20	Fifth	Air intake plenum in Stage 3 area extended
ar--1209	21	Sixth	Riser duct added.
	22	Sixth	Stair wall in Stage 3 moved.
ar--1211	23	Roof	Grid mesh roof area amended.
	24	Roof	Position of intakes to Stage 3 cooling towers amended.
ar--2501	25	East elevation	Amendment of incorrectly labelled stone facade finishes – the majority of stonework on this elevation is sandstone as depicted in the perspective images submitted with the original application. Note: ar-2500 south elevation needs no correction.