

Modification of Minister's Approval

Section 75W of the *Environmental Planning & Assessment Act 1979*

As delegate of the Minister for Planning under delegation executed on 4 April 2013, I approve the modification of the project application referred to in schedule 1, subject to the conditions in schedule 2.



Karen Jones

Director, Infrastructure Projects

DEVELOPMENT ASSESSMENT SYSTEMS AND APPROVALS

Sydney

9 July

2014

SCHEDULE 1

Project Approval:

MP 08_0236 granted by the Planning Assessment Commission on 24 November 2011.

For the following:

Stage 1 of the Googong Township Water Supply Project as described in the EA, including:

- A bulk water pumping station;
- A water recycling plant to treat sewage from the Googong Township to a standard suitable for non-potable urban re-use and discharge to the environment, and associated pumping station;
- Two sewage pumping stations
- Reservoirs for recycled and potable water; and
- Rising and distribution mains for potable water, recycled water and sewage.

Modification:

MP08_0236 MOD 2: Modify the project approval to provide an additional discharge point for release of water to the environment. Proposed works include a discharge structure, water storage tanks, additional reticulation (including a rising main) and a ventilation stack.

SCHEDULE 2 CONDITIONS

TERMS OF APPROVAL

Delete Condition of Approval A1 and replace with the following:

- A1 The Proponent shall carry out the project generally in accordance with the:
- (a) EA;
 - (b) Statement of Commitments;
 - (c) Googong Township Water Cycle Project Modification Assessment, prepared by Manidis Roberts and dated February 2013;
 - (d) ***Modification to Approved Project: Googong Township Integrated Water Cycle Project – Proposed Discharge Point at Googong Creek, prepared by RPS Manidis Roberts and dated March 2014*** and
 - (e) conditions of this approval.

WATER QUALITY

Delete Condition of Approval D5 and replace with the following:

- D5 The recycled water discharged to the environment ***or any water discharged to the environment through Discharge Point 3*** shall not exceed the water quality parameters identified in Table D1 below.

Table D1: Effluent Quality Limits

Parameter	Effluent discharge limits to environment	
	Units	90 th Percentile
BOD	mg/L	10
Suspended Solids	mg/L	10
TN	mg/L	10
TP	mg/L	0.5
TDS	mg/L	700
Faecal Coliforms	cfu/100mL	150
pH		6.5-8.0
Free Chlorine (residual)	mg/L	0.1
Nitrogen – Ammonia	mg/L	2
Oil & Grease	mg/L	2

If the results of water quality monitoring undertaken in accordance with the Water Management Plan in condition D8 indicates that the downstream ambient water quality criteria of the Queanbeyan River is exceeded as a result of the project, then the project shall be adjusted to reduce the concentration of the relevant parameters in the recycled water discharged to the environment.

Insert new Condition D5A

- D5A ***Prior to the discharge of any water to the environment through Discharge Point 3, evidence of compliance with the water quality parameters identified in Condition D5 must be provided for the Secretary's information.***