


Lighting Impact Statement

Connell Wagner as the electrical services consultant for the 88 Walker St development confirms the following intent in relation to the design of the lighting for the abovementioned project.

The Connell Wagner lighting design will be undertaken at detail design stage of the project in accordance with AS4282; 1997 Control of the Obtrusive Effects of Outdoor Lighting.

This standard nominates limitations on illuminance in areas adjacent to the development as well as implementation of direct uplighting.

Regards,

A handwritten signature in black ink, appearing to be 'Gabe Carter', written over the word 'Regards,'.

Gabe Carter
Electrical Engineer
09/03/09