



Department of Primary Industries

OUT14/418

20 JAN 2014

Ms Fiona Gibson
Industry, Social Projects and Key Sites
NSW Department of Planning and Infrastructure
GPO Box 39
SYDNEY NSW 2001

Fiona.Gibson@planning.nsw.gov.au

Dear Ms Gibson

Discovery Point, Wolli Creek Stage 1 (MP10_0030) Proposed Modification

I refer to your email dated 9 December 2013 requesting advice from the Department of Primary Industries (DPI) in respect to the above matter.

Comment by NSW Office of Water

The current Modification application includes the installation of infrastructure works associated with reticulation from the on-site water recycling facility to future stages/building (page 5). The Modification Report outlines that the provision of this infrastructure does not raise any additional impacts not already considered in the original assessment (page 7).

The Office of Water requests clarification on the source of the water for the on-site water recycling and whether it will only consist of roof runoff or if it will include groundwater. If the recycled water is also from groundwater a licence may be required from the NSW Office of Water.

For further information please contact Janne Grose, Planning and Assessment Coordinator (Penrith office) on 4729 8262 or at janne.grose@water.nsw.gov.au.

Yours sincerely

Tony Heffernan
Acting Executive Director Business Services