

Our ref: 09-181

28 September 2010

Coffey Projects
Level 10, BT Tower
1 Market St
SYDNEY NSW 2000

Attn: John Cordingly

Dear John,

**RE: AUSTRALIAN HEARING HUB AT MACQUARIE UNIVERSITY
RTA COMMENTS ON PROJECT APPLICATION**

Reference is made to your email dated 27 September 2010 concerning the RTA's comments related to compliance of the layout of the proposed car parking area including the access road and entry with AS2890.1 – 2004 and AS2890.2 – 2002.


We respond as follows:

1. The car parking spaces, aisle widths, grades, turn paths and driveway comply with AS2890.1 – 2004 on the following basis.
 - User class 2.
 - Entry queuing permitted in local access road off University Avenue.
 - Stack parking spaces and blind aisles in excess of 6 spaces length, only used in tenant allocated car parking areas.
2. Access for commercial vehicles from University Avenue to the delivery area on Basement 1 level complies with AS2890.2 – 2002 on the following basis:
 - General access for Medium Rigid Vehicles.
 - Access for Heavy Rigid Vehicles through reversing into basement only.

We trust that the above information is sufficient for your needs, however should you require further assistance, please contact the undersigned.

Yours faithfully,

WOOLACOTTS



Stephen Branch