

PAVEMENT SCHEDULE

ASPHALTIC CONCRETE (TYPE 1)

50mm THICKNESS ASPHALTIC CONCRETE (AC10) ON 150mm THICKNESS ASPHALTIC CONCRETE (AC14) ON 300mm THICKNESS RECYCLED UNBOUND GRAVEL (DGS 4.0) ON COMPACTED SUBGRADE CBR 15% MIN.

ASPHALTIC CONCRETE (TYPE 2)

50mm THICKNESS ASPHALTIC CONCRETE (AC10) ON 50mm THICKNESS ASPHALTIC CONCRETE (AC14) ON EXISTING ASPHALT SURFPAVE AC/LAYER TO BE INCREASED TO SUIT FINAL ROAD LEVELS AS REQUIRED

ASPHALTIC CONCRETE (TYPE 3)

50mm THICKNESS ASPHALTIC CONCRETE (AC10) ON 200mm THICKNESS RECYCLED UNBOUND GRAVEL (DGS 4.0) ON COMPACTED SUBGRADE CBR 2% MIN.

CONCRETE COVER SLAB

200mm THICKNESS 32MPa CONCRETE SLAB WITH REINFORCING BARS - 40 COVER BOTTOM SLABS EVERY 9m - SLABS POURED IN ALTERNATE SECTIONS

PAVEMENT (TYPE 2)

(COLOURED GUN METAL GREY) 100mm THICKNESS CONCRETE (N2) SLAB 50 TOP COVER ON 150mm THICKNESS FINE CRUSHED ROCK (DGR 20) 3% CEMENT STABILISED ON COMPACTED SUBGRADE CBR 10% MIN. (SEE PAVEMENT NOTE)

PAVEMENT (TYPE 3)

(COLOURED BLACK) 100mm THICKNESS CONCRETE (N2) SLAB 50 TOP COVER ON 150mm THICKNESS FINE CRUSHED ROCK (DGR 20) 3% CEMENT STABILISED ON COMPACTED SUBGRADE CBR 10% MIN. (SEE PAVEMENT NOTE)

PAVEMENT (TYPE 4)

30mm THICKNESS ASPHALTIC CONCRETE (AC3) ON 100mm THICKNESS FINE CRUSHED ROCK (DGR 20) ON 12% CEMENT STABILISED ON COMPACTED SUBGRADE CBR 10% MIN. (SEE PAVEMENT NOTE)


UNIT PAVERS (TYPE 5)

80mm UNIT PAVERS TO MATCH PREEXISTING NORTH OF NINA GRAY AVE ON 300mm SAND BEDDING ON 120mm THICKNESS FINE CRUSHED ROCK (DGR 20) ON 3% CEMENT STABILISED ON COMPACTED SUBGRADE CBR 10% MIN. (SEE PAVEMENT NOTE)

STAGE 2A


PAVEMENT NOTES

1. THE EXTENT OF PAVEMENT TYPES IN WALKER STREET IS SUBJECT TO DETAILED SITE INSPECTION AND IS SHOWN ON PLAN IN APPROXIMATE LOCATIONS ONLY.
2. EXISTING ASPHALT IS TO BE REMOVED IN AREAS WHERE EXISTING ASPHALT IS CRACKED AND PAVEMENT PATCHED WITH AC/L TO SUIT.
3. WHERE PROFLING OF THE EXISTING PAVEMENT EXTENDS INTO THE CLAY SUBGRADE ASPHALTIC CONCRETE PAVEMENT TYPE 3 SHALL BE USED.
4. ALL DGR AND DGS TO BE RECYCLED PRODUCTS (SUBJECT TO APPROVAL).





STAGE 3A

REFER DRAWING C204 FOR CONTINUATION




MAIN NORTHERN RAILWAY



Issue	Amendment	By	Date
1	COUNCIL DA SUBMISSION	EL	22/10/05
2	COUNCIL C SUBMISSION	EL	12/10/07
3	WALKER ST OFFSET FROM REMOVED	EL	15/05/08
4	WALKER STREET LEVELS LOWERED	EL	04/05/09
5	WALKER STREET CARBONWAY WIDENED	EL	28/05/09
6	ISSUED FOR CONSTRUCTION	EL	31/08/09
7	COVER SLAB ADDED OVER GAS MAIN	EL	15/09/09

1. Do not state the drawing title, dimensions & architectural drawings only.
2. Changes to be noted in consultation with specification.
3. All dimensions are to be given in metres unless otherwise stated.
4. All dimensions must be given in metres unless otherwise stated.
5. The information on this drawing is to be used for Walker Street works only. Refer to other drawings for other site infrastructure works.



CLIENT  
**Bilberga Developments Pty Ltd**

PROJECT  
**WATERPOINT**  
SITES 1A - 40 WALKER STREET  
RHODES NSW 2138

DRAWING TITLE  
**PAVEMENT LAYOUT PLAN SHEET 2**

DATE DRAWN  
20/08/09

PROJECT NUMBER  
3191

DRAWING NUMBER  
C201-V7

ISSUE  
7

SCALE  
1:200

DRAWN BY  
3191

ISSUE  
7