PCU015808

14 October 2010

Caroline Owen
NSW Department of Planning
GPO Box 39
Sydney NSW 2001

Department of Planning Received 2-2 001 2010 Scanning Room

Dear Ms Owen.

## Environmental Assessment Exhibition – MP 10\_0107 Residential Development – Buildings 1, 2 and 3 61 Mobbs Lane, Epping (Former Channel 7 site)

In response to the Public Notification to the above project, Integral Energy offers the following comments.

The estimated 29 townhouses under this application can be supplied with electricity initially sourced from the existing high voltage network. This supply will need to be of underground construction and will require the installation of a substation on the applicants site so that low voltage supplies can be made available to the apartment blocks.

The developer or their representative will need to submit an "Application for Connection of Load" to enable this connection of this load.

Full development of the former Channel 7 site will also require a number of new substation sites to be installed at suitable locations on site so that low voltage supplies can be made available to the various apartment blocks. This will require further assessment by Integral Energy when an "Application for Connection of Load" is submitted by the applicant to determine if electrical capacity is available and whether electrical headworks are required on the network.

Yours faithfully

Matthew Webb

Manager Strategic Asset Management

**Network Development** 

In reply please quote file no.: 2010/00451/001

Contact name John Phillips Direct phone 9853 6571 Fax 9853 6099 51 Huntingwood Drive Huntingwood NSW 2148. PO Box 6366 Blacktown NSW 2148. DX 8148 Blacktown Integral Energy Australia ABN 59 253 130 878 www.integral.com.au

Going further for you is what we do

